

**Fire Department Water Tanker Shuttle Accreditation**

Presented To: Asphodel-Norwood Township

**ACCREDITED FIRE STATIONS**

F.S Norwood (7)

F.S Westwood (7)

Date Test Passed: September 18<sup>th</sup> 2019

Flow Achieved: 415 I.G.P.M. 1,890 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose  
Elaine Rose  
Partner

This Certificate Expires on: September 1<sup>st</sup> 2024