



SECTION 11 ANNUAL REPORT

Drinking-Water System Number:	220000479
Drinking-Water System Name:	Norwood Drinking Water System
Drinking-Water System Owner:	The Corporation of the Township of Asphodel-Norwood
Drinking-Water System Category:	Large Municipal Residential
Period:	January 1, 2025 to December 31, 2025

<p><u><i>Complete if your Category is Large Municipal Residential or Small Municipal Residential</i></u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>Public access/notice via the web Public access/notice via Government Office</p> </div>	<p><u><i>Complete for all other Categories.</i></u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;">N/A</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;">NONE</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	--

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
NONE	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via government office
- Public access/notice via newspaper
- Public access/notice via Public request
- Public access/notice via a Public library

Describe your Drinking-Water System:

A groundwater well supply system consisting of 4 wells with sodium hypochlorite disinfection. The facility has on-line, alarmed, continuous monitoring for treated water free chlorine residual, treated water turbidity and distribution water free chlorine residual. An orthophosphate blend is added as a corrosion control measure.

List all water treatment chemicals used over this reporting period:

Sodium Hypochlorite – 12%, ClearHib Orthophosphate blend.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred.

- None

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
NONE					



Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Microbiological testing done under Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli OR Fecal Results (min#)-(max#)	Range of Total Coliform Results (min#)-(max#)	Number of HPC Samples	Range of HPC Results (min#)-(max#)
Raw – Well 1	52	0 - 0	0 - 0	Not Required	
Raw – Well 2	52	0 - 0	0 - 0	Not Required	
Raw – Well 3	45	0 - 0	0 - 0	Not Required	
Raw – Well 4	52	0 - 0	0 - 0	Not Required	
Treated	52	0 - 0	0 - 0	52	0 – 2
Distribution	153	0 - 0	0 - 0	153	0 – 229

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity, Raw Well 1	12	0.08 – 0.21	NTU
Turbidity, Raw Well 2	12	0.09 – 0.19	NTU
Turbidity, Raw Well 3	12	0.11 – 0.47	NTU
Turbidity, Raw Well 4	12	0.08 – 0.30	NTU
Turbidity Treated	182	0.00 – 0.28	NTU
Chlorine, Treated Pre Tower	8760	0.0 - 3.0	mg/L
Chlorine, Treated Pre Tower	184	1.47 – 2.11	mg/L
Chlorine, Treated Post Tower	8760	0.63 – 1.73	mg/L
Chlorine, Treated Post Tower	184	1.05 – 1.72	mg/L
Chlorine, Distribution	8760	0.00 – 1.90	mg/L
Chlorine, Distribution	179	0.97 – 1.67	mg/L
Fluoride (If DWS provides fluoridation)	n/a	n/a	n/a
Phosphorus	20	0.58 – 1.63	mg/L

NOTE: For continuous monitors use 8760 as the number of samples

*Instrument spikes and dips recorded by on-line instrumentation were a result of various maintenance and calibration activities.



Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Power interruptions may also cause an instrument reading to drop to zero. All events are reviewed for compliance with O. Reg. 170/03 and if warranted, are reported to the Ministry of Environment as Adverse Water Quality Incidents.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
DWWP 133-201. Apr. 21, 2017	Phosphorus	Jan 1, 2025 to Dec. 31, 2025	0.58-1.63	mg/l

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Sample Result	Exceedance
Antimony: Sb (ug/L) - TW	2025/03/03	<0.06	No
Arsenic: As (ug/L) - TW	2025/03/03	<0.20	No
Barium: Ba (ug/L) - TW	2025/03/03	143	No
Boron: B (ug/L) - TW	2025/03/03	20	No
Cadmium: Cd (ug/L) - TW	2025/03/03	0.003	No
Chromium: Cr (ug/L) - TW	2025/03/03	0.23	No
Lead: Pb (ug/L) - DW	2025/12/01	0.28	No
Mercury: Hg (ug/L) - TW	2025/03/03	0.01	No
Selenium: Se (ug/L) - TW	2025/03/03	0.24	No
Sodium: Na (mg/L) - TW	2022/10/06	36.4	Yes
Uranium: U (ug/L) - TW	2025/03/03	0.085	No
Fluoride Residual: Mean (mg/L) - TW	2021/03/24	<0.060	No
Nitrite (mg/L) - TW	2025/01/15	< 0.003	No
Nitrite (mg/L) - TW	2025/04/09	< 0.003	No
Nitrite (mg/L) - TW	2025/07/15	< 0.003	No
Nitrite (mg/L) - TW	2025/10/07	< 0.003	No
Nitrate (mg/L) - TW	2025/01/15	4.03	No
Nitrate (mg/L) - TW	2025/04/09	3.78	No
Nitrate (mg/L) - TW	2025/07/15	3.80	No
Nitrate (mg/L) - TW	2025/10/07	4.07	No



Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Summary of lead testing under Schedule 15.1 during this reporting period

Location Type	Number of Samples	Range of Lead Results (min#)-(max #)	Unit of Measure	Number of Exceedances
Plumbing	NONE*			
Distribution	4	0.01 – 0.29	Pb (ug/L)	0

*This system is exempt from plumbing sampling for lead. This system must collect distribution pH and alkalinity samples under the reduced sampling table during each sampling period in every 12-month period and distribution lead samples under the reduced sampling table during each sampling period in every third 12-month period.

Summary of Organic parameters sampled during this reporting period or the most recent sample results:

Parameter	Sample Date	Result Value	Exceedance
Alachlor (ug/L) - TW	2025/03/03	< 0.02	No
Atrazine (ug/L) - TW	2025/03/03	< 0.01	No
Atrazine + N-dealkylated metabolites (ug/L) - TW	2025/03/03	< 0.01	No
Azinphos-methyl (ug/L) - TW	2025/03/03	< 0.05	No
Benzene (ug/L) - TW	2025/03/03	< 0.32	No
Benzo(a)pyrene (ug/L) - TW	2025/03/03	< 0.004	No
Bromoxynil (ug/L) - TW	2025/03/03	< 0.33	No
Carbaryl (ug/L) - TW	2025/03/03	< 0.05	No
Carbofuran (ug/L) - TW	2025/03/03	< 0.01	No
Carbon Tetrachloride (ug/L) - TW	2025/03/03	< 0.17	No
Chlorpyrifos (ug/L) - TW	2025/03/03	< 0.02	No
Diazinon (ug/L) - TW	2025/03/03	< 0.02	No
Dicamba (ug/L) - TW	2025/03/03	< 0.2	No
1,2-Dichlorobenzene (ug/L) - TW	2025/03/03	< 0.41	No
1,4-Dichlorobenzene (ug/L) - TW	2025/03/03	< 0.36	No
1,2-Dichloroethane (ug/L) - TW	2025/03/03	< 0.35	No
1,1-Dichloroethylene (ug/L) - TW	2025/03/03	< 0.33	No
Dichloromethane (ug/L) - TW	2025/03/03	< 0.35	No
2,4-Dichlorophenol (ug/L) - TW	2025/03/03	< 0.15	No
2,4-Dichlorophenoxy acetic acid (2,4-D (ug/L) -TW	2025/03/03	< 0.19	No
Diclofop-methyl (ug/L) - TW	2025/03/03	< 0.40	No
Dimethoate (ug/L) - TW	2025/03/03	< 0.06	No
Diquat (ug/L) - TW	2025/03/03	< 1.00	No
Diuron (ug/L) - TW	2025/03/03	< 0.030	No
Glyphosate (ug/L) - TW	2025/03/03	< 1.00	No



Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Malathion (ug/L) - TW	2025/03/03	< 0.020	No
Metolachlor (ug/L) - TW	2025/03/03	< 0.010	No
Metribuzin (ug/L) - TW	2025/03/03	< 0.020	No
Monochlorobenzene (ug/L) - TW	2025/03/03	< 0.30	No
Paraquat (ug/L) - TW	2025/03/03	< 1.00	No
Pentachlorophenol (ug/L) - TW	2025/03/03	< 0.15	No
Phorate (ug/L) - TW	2025/03/03	< 0.010	No
Picloram (ug/L) - TW	2025/03/03	< 1.0	No
Polychlorinated Bichenysl(PCB) (ug/L) - TW	2025/03/03	< 0.040	No
Prometryne (ug/L) - TW	2025/03/03	< 0.030	No
Simazine (ug/L) - TW	2025/03/03	< 0.010	No
*THM (ug/L) – DW	2025/07/07	29	No
Terbufos (ug/L) - TW	2025/03/03	< 0.010	No
Tetrachloroethylene (ug/L) - TW	2025/03/03	< 0.35	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW	2025/03/03	< 0.20	No
Triallate (ug/L) - TW	2025/03/03	< 0.010	No
Trichloroethylene (ug/L) - TW	2025/03/03	< 0.44	No
2,4,6-Trichlorophenol (ug/L) - TW	2025/03/03	< 0.25	No
Trifluralin (ug/L) - TW	2025/03/03	< 0.020	No
Vinyl Chloride (ug/L) - TW	2025/03/03	< 0.17	No
MCPA (mg/L) - TW	2025/03/03	< 0.00012	No

*THM Results are shown as the highest of the 4 quarters.

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
None			