



Aquifer Capacity Study Report

**Norwood Water Supply Aquifer
Village of Norwood, ON**

D.M. Wills Project Number 21-7128



D.M. Wills Associates Limited

Partners in Engineering, Planning and
Environmental Services
Peterborough

August 2022

**Prepared for:
The Township of Asphodel-
Norwood**



Summary of Revisions

Revision No.	Revision Title	Date of Release	Summary of Revisions
0	Draft Report Submission	June 17, 2022	NA
1	Final Report Submission	August 18, 2022	Client Comments
2	Final Report for Council	August 19, 2022	Summary for Council

This report has been formatted considering the requirements of the Accessibility for Ontarians with Disabilities Act.

Table of Contents

1.0	Introduction	1
1.1	Site Location and Description	1
2.0	Background.....	1
2.1	The Norwood Esker	1
2.2	Norwood Drinking Water System	2
2.3	Historic Short-Term Pumping Tests	3
2.3.1	Historical Aquifer Characteristics.....	3
2.4	Pumping Test Constraints	4
3.0	Scope of Work	4
4.0	Geology	5
4.1	Physiography	5
4.2	Surficial Geology	6
4.3	Bedrock Geology.....	6
5.0	Subsurface Investigation	6
5.1	Drilling and Monitor Well Installation	6
6.0	Subsurface Profile.....	8
6.1	Southern Parcel.....	8
6.2	Northern Parcel	9
7.0	Cross Sections	10
8.0	Hydrogeological Context.....	10
9.0	Pumping Tests	11
9.1	Aquifer Parameter Results	12
9.1.1	Well 3 and Well 4 Transmissivity (T) and Hydraulic Conductivity (K)	12
9.1.2	Well 1B Transmissivity (T) and Hydraulic Conductivity (K).....	12
9.1.3	Well 2 Transmissivity (T) and Hydraulic Conductivity (K).....	13
9.2	Well 4 Pumping Test Analysis	13
9.2.1	Well 4 Pumping Test Conclusions	14
9.3	Well 3 Pumping Test Analysis	16
9.3.1	Well 3 Pumping Test Conclusions	17
9.4	Well 1B Pumping Test Analysis	18
9.4.1	Well 1B Pumping Test Conclusions	19
9.5	Well 2 Pumping Test Analysis	19
9.5.1	Well 2 Pumping Test Conclusions	20
10.0	Updated Groundwater Model - Norwood Municipal Water Supply	20

10.1 Discussion - Norwood Municipal Well Field 2022 Updated Groundwater Model	21
11.0 Predictive Modelling	22
11.1 Long-Term Pumping at the existing PTTW Rate	22
12.0 Conclusions	24
12.1 Conclusions	24
13.0 Statement of Limitations	26

Tables

Table 1 – Drilling Details	7
Table 2 - Summary of Particle Size Distribution for Southern Parcel	9
Table 3 - Summary of Particle Size Distribution for Northern Parcel	10
Table 4 – Pumping Test Details	11
Table 5 - Well 1B Pumping Test Aquifer Parameters Transmissivity (T) and Hydraulic Conductivity (K)	13
Table 6 - Well 2 Pumping Test Aquifer Parameters Transmissivity (T) and Hydraulic Conductivity (K)	13
Table 7 - Well 4 Pumping Test, Maximum Observed and Simulated Drawdowns	14
Table 8 - Well 3 Pumping Test & Observation Wells Observed & Simulated Drawdown	17
Table 9 - Well 1B Pumping Test - Observed and Simulated Drawdown	19
Table 10 - Well 2 Pumping Test - Observed and Simulated Drawdown	20
Table 11- Existing Municipal Pumping Wells, Simulated PTTW Long-Term Rate, and Simulated Drawdowns	22

Figures

Figure 1 – Site Location Plan
Figure 2 – Water Supply Well Locations
Figure 3 – Subsurface Investigation Plan
Figure 4 – Cross Section Locations
Figure 5 – Static Groundwater Level Contour Map
Figure 6 – Well 1B Composite Pumping Test
Figure 7 – Maximum Drawdown Vs. Distance from Well 4
Figure 8 – Well 4 Composite Pumping Test
Figure 9 – Maximum Drawdown Vs. Distance from Well 3
Figure 10 – Well 3 Composite Pumping Test
Figure 11 – Drawdown Cone of Wells 2, 3, and 4 Pumping at PTTW Rate

Appendices

- Appendix A – APP-A1 – Regional Physiography Map
APP-A2 – Regional Surficial Geology Map
APP-A3 – Regional Bedrock Geology Map
- Appendix B – Borehole Logs & Monitor Well Construction Details
- Appendix C – Geologic Cross-Sections
- Appendix D – Pumping Tests – Observation Well Details
- Appendix E – Aquifer Parameter Results for Well 3 & Well 4

Executive Summary

D.M. Wills Associates Limited (Wills) was retained by the Township of Asphodel-Norwood (Township) to complete an Aquifer Capacity Study (Study) for the Village of Norwood (Norwood) Water Supply Aquifer (Aquifer). The Study was requested to assess the capacity of the Municipal Well Field (including Water Supply Wells 1B, 2, 3, and 4) in context of the approved Permit to Take Water (PTTW).

Furthermore, the Study has been requested to determine whether the Aquifer can meet the future growth demands (20 year planning horizon) of the Township. A separate memo which evaluates the Aquifer capacity in relation to the Village's long term demand requirements to serve the projected development to 2042 will be submitted under separate cover.

The water supply for Norwood is provided by the Norwood Drinking Water System that includes four Water Supply Wells (Municipal Well Field) located on and to the east of the Norwood esker crest line. The Norwood esker is a glacial landform that was deposited during the Quaternary period consisting of permeable core deposits consistent with high energy deposition (including gravel, cobbles, and boulders), and lower permeability flank deposits consistent with lower energy deposition (including silt, clay, sand, and gravel).

In order to refine the understanding of the local geological conditions as they relate to the Aquifer's capacity, Wills' Study included subsurface investigations conducted on Township owned lands (Study Area), including:

- Southern Parcel – The Norwood Drinking Water System (42 Ridge Street, Norwood, Ontario), 1.6 hectare (ha)
- Northern Parcel - The Norwood Cemetery (40 Wellington Street, Norwood, Ontario), 4.3 ha

Wills approved Scope of Work to complete the Study included advancing 11 boreholes and installing 10 monitor wells between November 15, 2021 and December 2, 2022. Monitor wells and borehole locations were geodetically surveyed, and all monitor wells were subjected to constant head tests following well development. Four long-term (24 to 36 hour) pumping tests were completed on Water Supply Wells 1B, 2, 3, and 4 between December 9, 2021 and January 7, 2022, and static water level monitoring was conducted on the 10 monitor wells (observation wells) during the pumping tests.

Field data interpretation included geology, hydraulic conductivity (permeability K) obtained from grain size, monitor well testing and pumping tests, and analysis of Aquifer parameters including transmissivity (T), storativity (S), and K. Following completion of the field activities and data analysis, the 2018 groundwater model was revised, and predictive modelling was conducted in order to assess the capacity of the Aquifer in the context of the approved PTTW.

Based on Wills investigation, the following conclusions and recommendations are provided:

- Aquifer test parameters were generated from the pumping tests carried out on Wells 1B, 2, 3 and 4 and observation wells MW21-01 through MW21-10. While most of the

test data was relatively simple to process in order to produce aquifer parameters, some of the tests were a challenge to interpret. While this is not that unusual in aquifer test analysis, the reasons for these difficulties could have been because of the configuration of the aquifer:

- A long, relatively thin granular deposit, flanked by lower permeability deposits.
 - Variability (from boulders to sand, silt and clay) in the texture of the core deposits.
 - The minimal drawdowns experienced even at high pumping rates. The analytical methods are based on assumptions including an 'infinite acting' aquifer and a consistent aquifer saturated thickness as well as isotropic conditions. While these assumptions were mostly satisfied, the varying hydraulic conductivity and somewhat variable saturated aquifer thickness across the aquifer complicated analysis.
- The higher permeability deposits are quite variable in texture with significant percentages of silt and sand, and predominance of gravel and cobbles / boulders. The finer materials, especially the silt and trace to minor clay fractions will significantly affect the hydraulic conductivity of the formation.
- The aquifer test analyses involved repeated rounds of data analysis to establish representative aquifer parameters. A considerable amount of professional judgment was required to arrive at a set of parameters which were supported by the multiple lines of evidence from assessing previous reports and maps, and from computer modelling, which resulted in a consistent conceptual model of the groundwater system at Norwood.
- While a considerable volume of water moves toward the Municipal Well Field from the northeast along the Norwood esker, significant groundwater also moves from the northwest. Monitor wells MW21-01 to MW21-04 appear to experience detectable but limited drawdown especially with Well 4 pumping during the pumping test. The well logs indicate that much of the material encountered in MW21-01 to MW21-04 was silty sand with some sandy gravel layers or lenses, and appear to constitute the flank deposits or the edge of the flank deposits. However, a hydraulic connection does exist between the Municipal Well Field and these northwest monitor wells.
- To meet the Village's population requirements, the current pumping rates of the Municipal Well Field account for approximately 35% of the PTTW rate of 1,965 m³/day (averaging approximately 650 m³/day). The drawdown from pumping at this rate and pumping intermittently each day appear to be minimal. A consequence of this is that the capture zones determined by the 2022 modelling bear little resemblance to the current pattern of groundwater flow at current pumping rates as expected.
- The drawdown (decline in water level in the well) after 36 hours of pumping at 1,782.4 m³/day in Well 4 during the December, 2021 pumping test was 0.55 m, and the drawdown in Well 1B was between 7.68 to 8.05 m after 24 hours pumping at 1,477.6 m³/day. The drawdown in Wells 2 (at a rate of 494.4 m³/day) and 3 (at a rate of 1542.5 m³/day) were 0.70 m and 2.11 m respectively. The saturated portion of the

aquifer was approximately 9.93 m (Well 4), 8.45 m (Well 3), 10.74 (Well 1B), 7.4 (Well 2) in December 2021-January, 2022. Water levels appear to vary seasonally about 0.5 m in the area of the Norwood Transfer Station, north of the Village, and this could be the case in the area of the Municipal Well Field. If this seasonal fluctuation also occurs in the area of the Water Supply Wells, then there would be more water available in spring and early summer with water levels declining in late summer into the winter. The limiting factor in supplying large amounts of water is the limited saturated thickness combined with the screen setting of the existing Water Supply Wells.

- The groundwater model of Municipal Wells 2, 3 and 4 continuously pumping (20 years) at 655 m³/day each, for a total of 1,965 m³/day (the PTTW rate) was shown to be sustainable.
 - The simulated pumping levels were higher in elevation than the estimated pump intakes, indicating the wells can pump continuously without the water levels in the wells falling below the pump intakes.
 - Pumping continuously at the PTTW rate was shown to have no effect on Mill Pond and the Ouse River.

1.0 Introduction

D.M. Wills Associates Limited (Wills) was retained by the Township of Asphodel-Norwood (Township) to complete an Aquifer Capacity Study (Study) for the Village of Norwood's (Norwood) Water Supply Aquifer (Aquifer). The Study was requested to assess whether the municipal wells could continuously supply water at the PTTW rate (1,965 m³/day) without dewatering the aquifer or affecting nearby surface water bodies. Wills Study considered the following documents:

- Norwood Municipal Wells Updated Modelling Report, November, 2018, Wills;
- Hydrogeology Review, Municipal Groundwater Supply Report, July 10, 2018, Ted Rannie;

1.1 Site Location and Description

The Township owned lands (Study Area) that were subject to subsurface investigation as part of the Study are approximately 5.9 hectares (ha), and include two parcels:

- Southern Parcel – The Norwood Drinking Water System (42 Ridge Street, Norwood, Ontario), 1.6 ha
- Northern Parcel - The Norwood Cemetery (40 Wellington Street, Norwood, Ontario), 4.3 ha

The Study Area is shown on **Figure 1**. Note that Wills' Study Area also included Township owned lands directly adjacent to the Mill Pond, which will be described under the Northern Parcel due to the similar geological conditions encountered.

2.0 Background

2.1 The Norwood Esker

The Norwood esker is a glacial landform that was deposited during the Quaternary period. Quaternary esker deposits typically consist of permeable core deposits consistent with high energy deposition (including gravel, cobbles, and boulders), and lower permeability flank deposits consistent with lower energy deposition (including silt, clay, sand, and gravel).

The Norwood esker was formed at the end of the last ice age, when high volumes of sediment-laden glacial meltwater flowed through tunnels within and underneath the retreating ice sheets. Under these depositional conditions, heavier coarse-grained materials (i.e. gravel, cobbles, and boulders) were able to drop out of suspension in the centre of these flow regimes where water velocities were the highest. Lower water velocities towards the edge of these flows permitted lighter fine-grained materials (i.e. silt, clay, sand and finer gravel) to drop out of suspension and ultimately form the flank deposits of the Norwood esker. The Norwood esker is a relatively long and thin esker with moderate relief, which transects Norwood and locally contains the Aquifer.

2.2 Norwood Drinking Water System

The Norwood Drinking Water System includes four Water Supply Wells (Municipal Well Field) located on and to the east of the Norwood esker crest line, including Water Supply Wells 1, 2, 3, and 4 (Well 1, Well 2, Well 3, and Well 4). Additionally, Well 1B was constructed in December 2017 with the intention to replace Well 1, however, Well 1B has yet to be connected to the Norwood Drinking Water System. The locations of the Water Supply Wells are shown on **Figure 2**.

The Norwood Drinking Water System maintains one pump house with a treatment system, and one water tower, located at 42 Ridge Street, Norwood, Ontario. Specifics of the Norwood Drinking Water System are outlined below:

- Current Amended Permit To Take Water (PTTW) No. 7130-BMCT9C dated March 4, 2020 allows for a total combined water takings of 1,965 cubic metres per day (m^3/day), from the four existing Water Supply Wells (1, 2, 3, and 4).
- Well 1 (MECP Well Tag A002060) was originally constructed in 1949 (Well Record No. 51-2505), and was subsequently replaced by Well 1A (now Well 1) in March 2017 following demolition of Pump House No. 1, where it was housed. Well 1 is equipped with a submersible pump rated at 7.9 litres per second (L/s) ($683 \text{ m}^3/\text{d}$).
- Well 1B (MECP Well Tag A230643) was constructed in December 2017, directly northeast of Well 1, and was intended to replace Well 1 due to silting problems. Well 1B is currently not connected to the Norwood Drinking Water System.
- Well 2 (MECP Well Tag not available) was constructed in 1972 (Well Record No. 51-5882), and is located inside Pump House No. 2. Well 2 is equipped with a vertical turbine pump rated at 7.9 L/s ($683 \text{ m}^3/\text{d}$).
- Well 3 (MECP Well Tag not available) was constructed in 1993 (Well Record No. 134169), and is located on the crest of the Norwood esker within a concrete well pit, approximately 60 m northwest of Pump House No. 2. Well 3 is equipped with a submersible pump rated at 7.6 L/s ($683 \text{ m}^3/\text{d}$).
- Well 4 (MECP Well Tag A230644) was constructed in December 2017, and is located on the crest of the Norwood esker, southwest of Well 3. Well 4 is connected to the Norwood Drinking Water System and has been on-line since October 2021.

2.3 Historic Short-Term Pumping Tests

During individual step pumping tests completed in December 2017 and February 2018, the following results for the Water Supply Wells were determined:

- Well 4 could pump, in the short term (300 minutes), 20.8 L/s (1,800 m³/d) with a maximum drawdown of 0.28 metres (m). The drawdown remained at 0.28 m for 18 minutes (min) at which point the pump was shut down. Recovery to pre-pumping static water level (SWL) took 20 minutes. This demonstrates that the yield of Well 4 could be considerably higher, considering Well 4 reached equilibrium in terms of drawdown, and the rapid recovery.
- Well 3 sustained a flow of 10.4 L/s (897 m³/d) in 92 minutes with a maximum drawdown of 0.36 m. From 82 to 92 minutes into the test, the drawdown stabilized at 0.36 m. Recovery to the pre-pumping SWL took 30 minutes.
- Well 2 sustained a flow of 5.9 L/s (510 m³/d) with a maximum drawdown of 0.53 m after 80 minutes. From 41 to 80 minutes, the drawdown stabilized at 0.53 m. Recovery to the pre-pumping SWL took 18 minutes.
- Well 1B sustained a flow of 17.1 L/s (1,473 m³/d) with a maximum drawdown of 7.1 m. Drawdown increased slowly at the end of the test, at 230 minutes. Well 1B recovered to within 0.11 m of the pre-pumping SWL in 30 minutes. The available drawdown in Well 1B was 10.4 m, excluding the pump. Pumping at this high rate would likely dewatered Well 1B within a relatively short time.

From these well performance tests, it was concluded that Wells 2, 3, and 4 could sustain higher pumping rates. This was indicated by minimal drawdown, relatively high pumping rates, and rapid recovery, in addition to high efficiency at the pumping rates tested.

2.3.1 Historical Aquifer Characteristics

The approximate transmissivity values, as determined from the historical step tests were:

- Well 4: 18,697 m²/d
- Well 3: 3,363 m²/d
- Well 2: 775 m²/d
- Well 1B: 516 m²/d.

Well 1B is considered a bedrock well, however the 2018 pumping test indicated that the bedrock and saturated surficial deposits (sand, gravel) overlying the bedrock are hydraulically connected, meaning that much of the water pumped in this well could come from the surficial deposits. The other Water Supply Wells are screened within the overlying surficial deposits (Well 4 partially penetrates the bedrock).

In general, it is likely that the bedrock, and overlying surficial deposits, are hydraulically connected. The hydraulic conductivities (K) derived from grain size analysis in the surficial deposits were:

- Well 4, 3×10^{-2} m/s (2,592 m/d)

- Well 3, 4×10^{-3} m/s (346 m/d)
- Well 2, 1×10^{-3} m/s (86 m/d)
- Well 1B, 3×10^{-4} m/s (26 m/d)

Considering that Well 4 partially penetrates the bedrock, it is reasonable to assume that the transmissivity of the bedrock at Well 4 is similar to the transmissivity of the bedrock in Well 1B. Therefore, it is likely that most of the yield in Well 4 comes from the surficial deposits overlying the bedrock.

2.4 Pumping Test Constraints

Discussions with the licensed well contractor that completed the historic pumping tests, G. Hart & Sons Well Drilling Ltd. (G. Hart), indicated that Well 4 may be pumped at a higher rate than the 20.8 L/s rate used during the historical short-term pumping test. However, pumping test constraints were identified that could limit the potential to complete testing at higher rates. These constraints included:

- The diameter of Well 4 which could not accommodate a larger pump, as well as the available drawdown (difference between the SWL and the bottom of Well 4). The available drawdown in Well 4 is 9.0 m, however, with the pump located above the screen, the available drawdown is reduced to approximately 5 m. Available drawdown in the other Water Supply Wells will be reduced by approximately 4 m when accounting for the pumps in each well.
- The analytical plot of pumping rate versus drawdown for Well 1B indicates that the Q/s slope (pumping rate/drawdown) flattens at about 8.3 L/s. This flatter slope represents increased well losses, and lower well efficiency at higher pumping rates due to turbulence at the well screen.
- Small slope changes also occurred in the plots for the other Water Supply Wells, but were not as pronounced as in Well 1B.

3.0 Scope of Work

Wills approved Scope of Work to complete the Study included the following:

- 11 boreholes were advanced within the Study Area. The location of the boreholes considered the results of the 2018 step testing on the Water Supply Wells (Rannie, 2018). Boreholes were terminated on, or in close proximity to the underlying bedrock, or due to practical refusal on overlying cobble and boulder materials.
- Standard Penetration Tests (SPT) and split spoon sampling was completed when drilling methods permitted (detailed in **Section 5.0**), and the encountered soil stratigraphy and depth to groundwater was documented at each drilling location.
- 15 representative soil samples were collected and submitted to WSP Canada Inc. (WSP), a Canadian Certified Independent Laboratory (CCIL), in Peterborough, Ontario for particle size distribution and hydrometer testing.

- Ten 51 mm diameter PVC groundwater monitor wells were constructed and developed. All monitor wells were screened within the saturated portion of the Aquifer.
- A geodetic survey of the top of the Water Supply Wells, monitor well casings, and ground surface elevations was conducted on January 10, 2022 (Wills Survey).
- Constant head tests were conducted on each monitor well to determine hydraulic conductivities (K).
- Four long-term (24 to 36 hour) pumping tests were conducted on Wells 1B, 2, 3, and 4 by G. Hart Well Drilling (G. Hart), a Licensed Well Contractor.
- During all pumping tests, pressure transducers (Solinst leveloggers) were installed in the observation wells (monitor wells and Water Supply Wells) and the pumping well to monitor the water levels.
- Manual water levels were collected using a Solinst Water Level Tape throughout the duration of the pumping tests in all of the observation wells.
- Pumping rates were monitored by G. Hart during the pumping tests using a flow meter for pumping tests on Well 1B, Well 3, and Well 4. The pumping rate for the Well 2 pumping test was monitored through the municipal water treatment system. Due to the quantity of daily water taking needs exceeding 50,000 L/day, the pumping tests were registered with the Environmental Activity and Sector Registry (EASR), Service ID R-011-3154159764.
- During the Well 1B, Well 3, and Well 4 pumping tests, water was discharged through a pipe to the stormwater sewer on County Road 40, southeast of the Municipal Well Field. The discharged water from the Well 2 pumping test was directed to the water tower.
- Field data interpretation included geology; hydraulic conductivity (K) obtained from grain size, monitor well testing, and pumping tests; and analysis of Aquifer parameters including transmissivity (T), storativity (S), and hydraulic conductivity.
- Preparation of this Aquifer Capacity Study Report, including:
 - Description of field investigations and resulting data.
 - Geological and hydrogeological interpretation with respect to the Aquifer capacity.
 - An assessment of the Aquifer capacity with respect to the existing PTTW.

4.0 Geology

4.1 Physiography

The Study Area is situated within the physiographic region known as the Dummer Moraines (Chapman and Putnam, 1984), which is characterized by rough stony land adjacent to the Canadian Shield, and extends eastward from the Kawartha Lakes. Moraines within this region often contain angular fragments and blocks of limestone with numerous Precambrian boulders. High-level Ontario Geological Survey (OGS) mapping (2003)

suggests the Study Area is located within a spillway (glacial drainage channel) that cross-cuts the Norwood esker. The Regional Physiography Map showing the Study Area with respect to the OGS mapping is included in **Appendix A**.

4.2 Surficial Geology

Surficial geology mapped by the OGS (2003) suggests that the Study Area is located within two distinct surficial geology regions. The Northern Parcel mapping includes glaciofluvial river and delta topset facies, specifically gravelly deposits. The Southern Parcel includes ice-contact stratified deposits of sand and gravel, minor silt, clay and till found in moraines, eskers, kames and crevasse fills.

The Regional Surficial Geology Map showing the Study Area with respect to the OGS mapping is included in **Appendix A**.

Based on the information obtained during Wills' Investigation, the native overburden material is generally aligned with the depositional models and includes predominantly sand with layers of gravel, and lesser amounts of silt, clay, and occasional cobbles / boulders on the Northern Parcel. The Southern Parcel overburden was found to be coarser-grained, including cobble / boulder rich gravels with layers of sand, and minor silt and clay fractions. The deposits on the Southern Parcel were generally aligned with high-energy depositional environments associated with the core deposits of the Norwood esker, and the deposits on the Northern Parcel were representative of lower-energy environments where investigated.

4.3 Bedrock Geology

Although bedrock classification was outside of Wills' Scope of Work, OGS mapping (1986-1990) suggests the underlying bedrock includes limestone, dolostone, shale, arkose, and sandstone belonging to the Upper Ordovician Formation of the Ottawa and Simcoe Groups. The Bedrock Geology Map is included in **Appendix A**.

5.0 Subsurface Investigation

5.1 Drilling and Monitor Well Installation

Soil and groundwater conditions within the Study Area were assessed via subsurface investigation (Wills' Investigation) that included advancing boreholes and installing monitor wells. Canadian Environmental Drilling & Contractors Inc. (Canadian Environmental), and Insitu Contractors Inc. (Insitu) were retained as the drilling contractors. Under the supervision of Wills staff, Canadian Environmental advanced nine boreholes between November 15 and November 30, 2021. Insitu advanced two boreholes between November 29, 2021 and December 2, 2021. All boreholes were completed as monitor wells, with the exception of BH21-11 that was terminated above the saturated zone due to refusal on presumed boulder / cobble material. Following refusal, BH21-11 was backfilled with bentonite pellets in accordance with Ontario Regulation 903.

Details of the drilling activities are summarized in **Table 1** below.

Table 1 – Drilling Details

Monitor Well / Borehole ID	Drilling Contractor	Drilling Method	Depth
MW21-01	Canadian Environmental	8" Hollow Stem Auger & SS sampling	8.25 m
MW21-02	Canadian Environmental	8" Hollow Stem Auger & Mud Rotary with SS sampling	16.80 m
MW21-03	Canadian Environmental	6" Solid Stem Auger & Mud Rotary With SS sampling	17.50 m
MW21-04	Canadian Environmental	6" Solid Stem Auger & Mud Rotary With SS sampling	11.50 m
MW21-05	Canadian Environmental	8" Hollow Stem Auger & Mud Rotary with SS sampling	23.10 m
MW21-06	Canadian Environmental	8" Hollow Stem Auger & SS sampling	10.00 m
MW21-07	Canadian Environmental	Mud Rotary with SS sampling	27.80 m
MW21-08	Canadian Environmental	Mud Rotary with SS sampling	26.95 m
MW21-09	Insitu	Sonic Drilling with Continuous sampling	26.50 m
MW21-10	Insitu	Sonic Drilling with Continuous sampling	30.65 m
BH21-11	Canadian Environmental	8" Hollow Stem Auger & Mud Rotary with SS sampling	15.85 m

*MW – Monitor Well BH – Borehole SS – Split Spoon m - Metres

Monitor wells were constructed using 2" PVC pipe with 10 point slotted well screens. The annular space was filled with No. 3 Quartz Sand to approximately 0.3 – 0.6 metres (m) above the top of the screen. Holeplug bentonite 3/8" chips were used to seal the annular space above the sand to the existing ground surface. The 10 monitor wells were capped with J-plugs and protected using steel monuments equipped with locks. Monitor wells were developed by purging at least three well volumes with a submersible pump and dedicated Waterra tubing prior to any sampling or hydraulic testing activities.

Subsurface soil samples collected during Wills' Investigation were field classified on the basis of grain size, stratigraphy, and relative soil compactness. Fifteen representative soil samples were collected and submitted to WSP for particle size distribution, including sieve and hydrometer analysis.

Borehole and monitor well locations are shown on the Subsurface Investigation Plan included as **Figure 3**. Borehole logs detailing the encountered subsurface conditions and monitor well construction details are included in **Appendix B**.

6.0 Subsurface Profile

6.1 Southern Parcel

Six boreholes (MW21-05, MW21-07, MW21-08, MW21-09, MW21-10, and BH21-11) were advanced on the crest of the Norwood esker. Due to the steep gradients on the northwest property boundary of the Southern Parcel, drilling pads comprised of granular fill were constructed at surface to facilitate the drilling activities. The drilling pads extended to a maximum depth of 2.7 meters below grade (mbg), and are excluded from the stratigraphic descriptions below (shown on the borehole logs in **Appendix B**).

All boreholes advanced on the Southern Parcel were terminated due to practical refusal in cobble/boulder material at depths ranging from 15.9 to 30.7 mbg. With the exception of BH21-11 (terminated at 15.9 mbg), all boreholes were assumed to have been terminated proximal to the bedrock-overburden contact based on Wills' review of the MECP Water Well Records for the Water Supply Wells and corresponding bedrock elevations.

The stratigraphy of the Southern Parcel generally includes a thin layer of silty sand topsoil, underlain by sand with varying amounts of silt, gravel, and cobbles / boulders, and ranged in composition from silty sand (MW21-10 and BH21-11) to gravelly sand (MW21-09) with cobbles. The sand generally contained some silt and trace amounts of clay.

Gravel was encountered in all boreholes and was the predominant soil type found on the Southern Parcel. The gravel was found to be interbedded with sand, and was described as containing trace sand, to sand and gravel. This material generally contained trace to some silt, and trace amounts of clay (generally less than 4%). Cobble / boulder material was frequently encountered in the gravel units, and the content was observed to increase with depth (general coarsening downwards).

Nine laboratory particle size distribution analyses were completed on samples of the gravel material. The results are summarized in **Table 2** on the basis of the Unified Soil Classification System (USCS). Note that cobble / boulder material is not reflected in the particle size distributions, and the presence of this material was determined based on observations made during the drilling activities (e.g. grinding augers and recovery of freshly broken rock fragments).

Table 2 - Summary of Particle Size Distribution for Southern Parcel

Location ID	Sample No.	Gravel (%)	Sand (%)	Silt (%)	Clay (%)
MW21-05	SS-10	40	46	11	3
MW21-05	SS-15	3	83	11	3
MW21-07	SS-12	44	40	13	3
MW21-08	SS-6	57	28	12	3
MW21-08	SS-9	45	35	16	4
MW21-09	ST-4A	81	18	< 1	< 1
MW21-09	ST-9	56	30	11	3
MW21-10	ST-7B	34	38	22	6
MW21-10	ST-10	53	35	7	5

6.2 Northern Parcel

Four boreholes (MW21-01, MW21-02, MW21-03, and MW21-04) were advanced on the Northern Parcel, as well as MW21-06 that was advanced directly adjacent to the Mill Pond. Boreholes were terminated at depths ranging from 8.3 to 17.5 m due to practical refusal on cobble / boulder material, and were assumed to be proximal to the bedrock-overburden contact. The stratigraphy of the Northern Parcel generally includes a thin layer of silty sand topsoil, underlain by sand. Sand material was encountered beneath the topsoil at all borehole locations on the Northern Parcel, including adjacent to the Mill Pond. The sand was found to be variably interbedded with gravel, and generally contained some silt, trace amounts of gravel and clay, and occasional cobbles / boulders. The sand contained interbeds of fine to coarse grained fractions, and was generally described as silty within the lower 2 m prior to borehole termination. Cobble / boulder content was found to increase proximal to the termination depth.

Six laboratory particle size distribution analyses were completed on samples of the sand material. The results are summarized in **Table 3** on the basis of the Unified Soil Classification System (USCS).

Table 3 - Summary of Particle Size Distribution for Northern Parcel

Location ID	Sample No.	Gravel (%)	Sand (%)	Silt (%)	Clay (%)
MW21-01	SS-5	0	61	35	4
MW21-02	SS-11B	0	70	25	5
MW21-03	SS-7	3	76	17	4
MW21-03	SS-11	4	70	22	4
MW21-04	SS-8A	3	83	11	3
MW21-06	SS-7	3	76	17	4

7.0 Cross Sections

Based on Wills Investigation, three representative cross sections of the Study Area were constructed. Cross Section A-A' and B-B' are generally aligned west to east through the Study Area, and Cross Section C-C' is aligned south to north along the Norwood Esker.

The geology depicted on the Cross Sections is congruent with the current understanding of the Norwood esker core deposits. It should be noted that based on the locations of the boreholes with respect to the cross section lines (borehole data transposed onto the cross section line), the lateral extent and configuration of the stratigraphic contacts beyond the boreholes locations cannot be confirmed, and are interpreted with a higher degree of uncertainty.

Within the core of the Norwood esker, the water table is encountered at an approximate elevation of 197.3 meters above sea level (masl), and the saturated zone is observed to be generally within the coarser Norwood esker deposits.

The locations of the cross section lines are shown on **Figure 4**, and detailed cross sections showing the interpreted stratigraphy are include as **Appendix C**.

8.0 Hydrogeological Context

The Aquifer is an esker deposit that is unconfined and is limited in width but much longer in length. Methods have been designed to determine if the flow to the wells during the pumping test was horizontally radial and whether the Aquifer appears to be infinite acting. These conditions are met for the Norwood Aquifer except in a few cases where noted.

The Aquifer is characterized by northeast-southwest trending permeability zones with high permeability core deposits and lower permeability flank deposits. Therefore, it is not homogeneous or isotropic (similar characteristics in terms of grain size and aquifer parameters in all directions) and the saturated portion of the aquifer itself is somewhat variable with minor differences in thickness (7-11 m thick). However, the contrast in

homogeneity and anisotropy is minor compared to deposits in other areas that are interbedded or bounded by aquitards of much lower permeable material.

The piezometric surface (in this case, the water table) slopes with a gentle northeast-southwest decline in elevation along the trend line of the Norwood esker and with a minor component of groundwater flow from west to east in the area of the Municipal Well Field, as shown on **Figure 5**. This is the gradual slope of the horizontal hydraulic gradient. The drawdown of the pumping wells was a maximum of 0.55 m (with the exception of Well 1B) which is approximately 5% of the saturated thickness. The pumping wells are only partially penetrating the saturated portion of the aquifer as the screen lengths are less than the saturated thickness of the aquifer. Well diameters are small but not zero with some wellbore storage possible. This can usually be determined with diagnostic methods. Despite these deficiencies, the assumptions of the various methods of aquifer analysis were substantially met.

9.0 Pumping Tests

The pumping tests were conducted to assess the performance of the wells over sustained pumping activity and the effect of this prolonged pumping on the Aquifer as a whole. The pumping rate for each test was determined by referencing the maximum pumping rates achieved during the December 2017 and February 2018 step tests, as described in the following reports:

- Hydrogeology Review, Municipal Groundwater Supply, Norwood, Ontario (Final Report), August 2018, Ted Rannie M.Sc. P. Geo. (Report 18-8.1)
- Norwood Municipal Wells Updated Modelling (Final Report), November 2018, D.M. Wills Associates Limited (Wills Project No. 7128)

The maximum pumping rate for Well 2 was limited due to its location within the pumping house and the maximum pumping rate of the pump installed in the well.

G. Hart completed four pumping tests within the Study Area. The pumping tests were conducted on Well 1B, Well 2, Well 3, and Well 4. Details of the pumping tests are included in **Table 4** below.

Table 4 – Pumping Test Details

Pumping Well	Pumping Test Date	Duration	Max Pumping Rate (Average)
Well 1B	December 9 – December 10, 2021	24 hours	270 USGPM
Well 2	December 16 – December 17, 2021	24 hours	90.67 USGPM
Well 3	January 6 – January 7, 2022	24 hours	283 USGPM
Well 4	December 7 – December 8, 2021	36 hours	326.5 USGPM

*USGPM – US Gallons Per Minute

Real-time data logging technology (Solinst Leveloggers) was employed at all wells to record the drawdown and groundwater level fluctuations resulting from the pumping tests. Manual monitoring of the groundwater levels in the observation wells was conducted using a Solinst water level tape. The measuring points of the wells (the top of the PVC casing for the monitor wells and top of metal casing for the Water Supply Wells) was determined using survey data collected by Wills. The locations and well identifiers of the wells used for each pumping test are shown on **Figure 4**.

Well details, including SWL measured in the observation wells prior to the initiation of each pumping test are summarized in **Appendix D**.

9.1 Aquifer Parameter Results

9.1.1 Well 3 and Well 4 Transmissivity (T) and Hydraulic Conductivity (K)

The results represent the T value between the pumping well and the monitor well in question. For instance, T can vary between Well 3 and a specific observation well and Well 4 and the same observation well. T is then divided by the average saturated thickness of the aquifer between the pumping well and the specific observation well, to obtain hydraulic conductivity (K). The latter values are used in the groundwater model.

T determined by different analytical methods can vary. The geometric mean (geomean) of T is determined between the Neuman and Moench methods of analysis as these are most applicable to the Norwood Aquifer. These geometric means are then divided by the average saturated thickness to obtain K values.

The drawdown results in MW21-01 to MW21-04 should be regarded with caution as the actual drawdown values are minimal (less than 10 mm). Nevertheless, pumping of Well 3 and Well 4 at the rates indicated did influence the water levels in MW21-01 to MW21-04. The current pumping rates of the Water Supply Wells likely have a very small influence on the water levels in these monitor wells. The extent of the drawdown cone is related to the pumping rate and the K values of the materials between the pumping well and the observation wells. The Aquifer parameter results for Well 3 and Well 4 from the pumping tests are included in **Appendix E**.

9.1.2 Well 1B Transmissivity (T) and Hydraulic Conductivity (K)

Table 5 details aquifer parameters derived from the pumping test on Well 1B. Due to the limited drawdown in the observation wells during the pumping test (less than 10 mm which can be confused with natural variations in water levels) and the disjointed drawdown response in Well 1B shown in **Figure 6**, possibly from other Water Supply Wells pumping, the observation well data analysis did not yield clearly defined aquifer parameters.

Table 5 - Well 1B Pumping Test Aquifer Parameters Transmissivity (T) and Hydraulic Conductivity (K)

Monitor	T m ² /day	K m/d	Saturated Thickness m	K m/sec
WELL 1B Pumping WELL 1B OBS	-	-	-	-
Neuman	486	45.2	-	-
Moench	486	45.2	-	-
Geomean	486	45.2	10.74	5.23E-4

9.1.3 Well 2 Transmissivity (T) and Hydraulic Conductivity (K)

Table 6 details aquifer parameters derived from the pumping test on Well 2.

Table 6 - Well 2 Pumping Test Aquifer Parameters Transmissivity (T) and Hydraulic Conductivity (K)

Monitor	T m ² /day	K m/d	Saturated Thickness m	K m/sec
Well 2 OBS	-	-	-	-
Neuman	1384	187.0	7.4	2.16E-3
Tartakovsky- Neuman	1593	215.3	7.4	2.49E-3

The observation wells produced minimal drawdown at the Well 2 pumping rate and were examined but could not be analyzed effectively for aquifer parameters.

9.2 Well 4 Pumping Test Analysis

Analysis on the Well 4 pumping test was conducted first as it was of longest duration (36 hours) and in the core deposits of the Norwood esker.

The pumping test on Well 4 began at 10:05 a.m. December 7, 2021 and the pumping phase ended December 8, 2021 at 8 p.m. During the pumping test on Well 4 the municipal water supply was still in operation. As such, Wells 1, 2, and 3 pumped 468.97 m³, 10.37 m³, and 143.93 m³ independent of the pumping test on December 7, 2022 and 579.07 m³, 0.67 m³, and 1.3 m³ respectively, on December 8, 2021.

The pumping of Well 3 on December 7 may have affected the response in Well 4 during the pumping test, although the pumping appeared to be before the test on Well 4 began and recovery in the Water Supply Wells is rapid. Due to the distance between Well 4, Well 1, and Well 2, and the relatively low pumping rates, these wells were unlikely to have affected the response in Well 4.

Table 7 details the drawdown response at the end of the pumping phase in the observation wells and Well 4, during the Well 4 pumping test. Furthermore, the **Table 8** provides the model simulated drawdown.

Table 7 - Well 4 Pumping Test, Maximum Observed and Simulated Drawdowns

Observation Well	Observed Drawdown (m)	Distance from Pumping Well (m)	Simulated Drawdown (m)	Model Corrected Drawdown Pumping Well (m)
Well 4	0.55	0.0	0.41	0.44
MW21-07	0.31	19.1	0.34	-
MW21-08	0.28	24.8	0.22	-
Well 3	N/A	32.9	0.28	-
MW21-09	0.26	61.6	0.23	-
MW21-05	0.26	62.6	0.25	-
MW21-10	0.26	106.5	0.18	-
Well 2	0.10	125.6.0	0.14	-
MW21-04	0.03	134.4	0.05	-
MW21-03	0.04	153.9	0.06	-
Well 1B	0.08	161.4	0.09	-
MW21-02	0.10	177.5	0.06	-
MW21-01	0.04	303.0	0.03	-
MW21-06	0.0	696.1	0.0	-

9.2.1 Well 4 Pumping Test Conclusions

In theory, drawdown diminishes with distance from the pumping well in a homogeneous aquifer. MW21-07, MW21-09, MW21-05, and MW21-10 appear to be in a relatively homogeneous aquifer with limited drawdown at a high pumping rate (1,782.4 m³/day), following the predictable pattern.

Plotting the maximum drawdown on a linear scale with the distance on a logarithmic scale can illustrate the extent of the cone of influence of the pumping well at the specified pumping rate. The radius of the drawdown cone could exceed 700 m in a northwest-southeast direction. The data indicates the drawdown cone is larger along the trendline of the Norwood esker. However, from as close as 19.1 m (MW21-07) from the pumping well, the drawdown is minimal (0.31 m) at the pumping test rate. At MW21-10 (106.5 m from the pumping well) drawdown was 0.26 m.

Simulation of the Well 4 pumping test (the modelling details are discussed below) yielded the simulated drawdowns in column four in **Table 7** above. These simulated values are very

close to the observed values and give confidence in the model assigned hydraulic conductivity values which were obtained from pumping tests.

The corrected drawdown is calculated for the pumping well using the Peaceman formula and is 0.44 m. The model gives drawdown in the cell in which the well is located and this must be corrected for the well diameter. The simulated corrected drawdown in the pumping well assumes 100% efficiency when pumping. Well 4 shows minimal inefficiency as the observed drawdown was 0.55 m. Pumping wells almost always show some degree of inefficiency at high pumping rates.

Figure 7 is a graph of the maximum drawdown compared to the distance of the observation well from pumping Well 4 and thus an estimate of the cone of influence when pumping at the pumping test rate. The radius of the cone of influence for a drawdown of 0.01 m is approximately 700 m after 36 hours pumping.

Figure 8 is a composite plot of the available drawdown data. This plot has a horizontal axis of time/radius² and a vertical axis of drawdown in metres. Radius is the distance from the pumping well to the observation well. According to theory, for wells located in the same pumped aquifer, drawdowns will fall on the same curve on a composite plot. The composite plot for the Well 4 pumping test illustrates that MW21-05, MW21-07, MW21-08, and MW21-09 fall more or less on the same curve. The curve for MW21-10 lies to the left of the MW21-07 to MW-09 group, indicating it could be in a different zone of the aquifer which may have different aquifer characteristics. Furthermore, MW21-05 plots to the right of the MW21-07 to MW-09 group. MW21-01, MW-02, MW-03, and MW21-04 also appear to be in a different aquifer or part of the aquifer with different characteristics.

The Well 4 drawdown curve is significantly displaced from the other curves. This may be because of wellbore (casing) storage affecting the response or that the well is in a much higher hydraulic conductivity field zone, or both. Wellbore storage is a phenomenon that occurs at the commencement of pumping a well when the compressibility and volume of the wellbore fluid dominates the flow over groundwater entering the wellbore (screen) from the formation. At the start of pumping, the production at surface is due to the expansion of the water in the wellbore, and not the surrounding aquifer. There is a time lag when the pumping rate becomes consistent with the screen entrance rate from the aquifer and this time lag defines the wellbore storage period.

The plot of Well 4 pumping with Well 4 also as the observation well (Well 4 obs) shows a drawdown vs time data curve with log-log axes which curve concave upward indicating increasing drawdown with time in a pattern that does not show the Theis curve response i.e. a curve concave downward eventually become parallel or sub-parallel with the x-axis. This likely indicates that the well is located in a very high hydraulic conductivity zone that is relatively long and narrow. During pumping of the well, the well 'sensed' a lower hydraulic conductivity boundary and thus drawdown increased more quickly to maintain the same pumping rate. This pattern does not occur in another well to the same extent. In the Well 3 pumping test, the Well 3 data exhibits a straight line with a slight upturn of the curve at late time.

Wills decided to use the high hydraulic conductivity result obtained during the 2018 step testing in the model because of the challenge to obtain T from the Well 4 drawdown

observations in the Well 4 pumping test. The Well 4 pumping test was simulated in the model and it was found that a high hydraulic conductivity was required in the area around Well 4 to obtain the observed drawdown response in the pumping well in addition to the nearby observation wells. A hydraulic conductivity of 3×10^{-2} metres per second (m/sec) (2,592 m/day) for the sediments around Well 4 from step testing in 2018, was assigned in the model in a relatively thin, long strip more or less in the centre of the Norwood esker spanning the model domain. This hydraulic conductivity represents the core deposits of the Norwood esker which appear to have a smaller width than in the 2018 version of the model. Other hydraulic conductivities assigned to the model were consistent with the results of the aquifer testing detailed in **Appendix E**.

9.3 Well 3 Pumping Test Analysis

The pumping test on Well 3 began at 12:30 p.m. January 6, 2022 at a rate of 1542.5 m³/d. The pumping phase ended January 7, 2022 at 12:30 p.m. During the pumping test on Well 3 the municipal water supply was still in operation. As such, Wells 1, 2, and 3 pumped 138.81 m³, 475.94 m³, and 1.14 m³ on January 6, 2022 and 134.4 m³, 541.01 m³, and 1.14 m³ respectively on January 7, 2022. These wells were pumped before and after the Well 3 pumping test, so likely had a minimal effect on the Well 3 pumping test drawdowns. Due to the distance from Well 3 to Well 1 and Well 2, and the relatively low pumping rates, these wells were unlikely to have affected the response in Well 3 or the observation wells.

Table 8 shows the drawdown response at the end of the pumping phase in the observation wells during the Well 3 pumping test as well as simulated results from the 2022 groundwater model.

Table 8 - Well 3 Pumping Test & Observation Wells Observed & Simulated Drawdown

Observation Well	Observed Drawdown (m)	Distance from Pumping Well (m)	Simulated Drawdown (m)	Corrected Drawdown Pumping Well (m)
Well 3	2.11	0.11	0.98	1.21
Well 4	0.23	32.9	0.21	-
MW21-08	0.28	33.7	0.14	-
MW21-09	0.26	38.9	0.20	-
MW21-07	0.21	51.7	0.20	-
MW21-10	0.26	76.1	0.16	-
MW21-05	0.26	89.5	0.15	-
Well 2	0.1	93.3	0.13	-
Well 1B	0.08	128.6	0.08	-
MW21-04	0.04	142.1	0.02	-
MW21-03	0.05	145.4	0.03	-
MW21-02	0.1	162.9	0.03	-
MW21-01	0.03	275.6	0.02	-
MW21-06	0.0	655.7	0.0	-

9.3.1 Well 3 Pumping Test Conclusions

The corrected drawdown is calculated for the pumping well using the Peaceman formula and is 1.21 m. The model gives drawdown in the cell in which the well is located and this must be corrected for the well diameter. The simulated corrected drawdown in the pumping well assumes 100% efficiency when pumping. Well 3 shows some inefficiency as the observed drawdown was 2.11 m. Pumping wells almost always shows some degree of inefficiency at high pumping rates.

Figure 9 is a graph of the maximum drawdown compared to the distance of the observation well from pumping Well 4 and thus an estimate of the cone of influence when pumping at the pumping test rate. The radius of the cone of influence is approximately 180 m at the pumping test rate after 24 hours of pumping.

Figure 10 is a composite plot of the available drawdown data. This plot has a horizontal axis of time/radius² and a vertical axis of drawdown in metres. Radius is the distance from the pumping well to the observation well. The composite plot shown on **Figure 10** for the Well 3 pumping test shows that the drawdown curves for all wells except the pumping well itself and MW21-03 more or less fall on the same curve. Displacement on the Y-axis is a synonym

for drawdown. The curve for MW21-03 is offset from the main group possibly indicating a part of the aquifer with different aquifer characteristics and parameters.

Well 3, the pumping well, is significantly displaced from the other curves. This may be due to wellbore storage affecting the response or the well is in a much higher hydraulic conductivity field zone, or both. Modelling indicates the hydraulic conductivity of the material surrounding Well 3 is consistent with the results of the Aquifer testing and the results of the 2018 Aquifer testing (Rannie, 2018).

9.4 Well 1B Pumping Test Analysis

The pumping test on Well 1B started December, 9, 2022 at 2:00 p.m. and ran for 24 hours to 2:00 p.m. December 10, 2021 at a pumping rate of 1477.6 m³/d. During the pumping test on Well 1B the municipal water supply was still in operation. As such, on December 9, 2021, Well 1 pumped 240.81 m³, Well 2 pumped 15.88 m³ and Well 3 pumped 348.34 m³ independent of the pumping test. Well 1 and Well 2 were operated in the morning before the Well 1B pumping test was started. Well 3 was operating at approximately 10 p.m. December 9, 2021 and may have had a slight impact on the response in Well 1B. On December 10, 2021, Well 1 pumped 162.61 m³, Well 2 pumped 2.25 m³, and Well 3 pumped 593.62 m³. Well 2 was operated during the Well 1B pumping test but the rate was negligible. Well 1 and Well 3 were operated after the Well 1B pumping test was completed. The operation of Well 3 during the Well 1B pumping test indicates there is minimal interference between wells at current pumping rates.

Table 9 below details the drawdown response at the end of the pumping phase in the observation wells, and Well 1B during the Well 1B pumping test. Furthermore, the table provides the model simulated drawdown.

Table 9 - Well 1B Pumping Test - Observed and Simulated Drawdown

Observation Well	Observed Drawdown (m)	Distance from Pumping Well (m)	Simulated Drawdown (m)	Corrected Drawdown Pumping Well (m)
Well 1B	7.68-8.05	0.11	2.18	3.21
Well 2	N/A	38.3	0.23	-
MW21-10	0.04	76.1	0.13	-
MW21-09	0.04	119.1	0.09	-
Well 3	0.07	128.6	0.07	-
Well 4	0.09	161.4	0.05	-
MW21-08	0.03	156.3	0.05	-
MW21-02	0.01	177.5	0.02	-
MW21-07	0.03	179.6	0.05	-
MW21-03	0.02	188.2	0.01	-
MW21-01	0.0	196.7	0.03	-
MW21-05	0.01	208.8	0.04	-
MW21-04	0.02	228.8	0.01	-
MW21-06	0.01	555.6	0.0	-

9.4.1 Well 1B Pumping Test Conclusions

The observed drawdown in the pumping well, Well 1B, was between 7.68 and 8.05 m during the test and confirms the inefficiency of this well when pumped at high rates as first detailed in Rannie (2018). However, the data and the modelling also show that the major drawdown of the water table is limited to the immediate area of Well 1B.

9.5 Well 2 Pumping Test Analysis

The Well 2 pumping test was started December 16, 2021 at 11:15 a.m. and ran for 24 hours to 11:15 a.m. December 17, 2021 at an average pumping rate of 497.13 m³/d. Prior to and following the pumping test on Well 1B, the Norwood Drinking Water System was in operation. As such, the other Water Supply Wells pumping on December 16, 2021 were Well 1, which pumped 137.72 m³, and Well 3 which pumped 1.19 m³. On December 17, 2021, Well 1 pumped 181.44 m³, and Well 3 pumped at 1.21 m³. Wells 1 and Well 3 were not pumping during the Well 2 pumping test.

Table 10 below details the drawdown response at the end of the pumping phase in the observation wells, and Well 2 during the Well 2 pumping test. Furthermore, the table

provides the model simulated drawdown.

Table 10 - Well 2 Pumping Test - Observed and Simulated Drawdown

Observation Well	Observed Drawdown (m)	Distance from Pumping Well (m)	Simulated Drawdown (m)	Corrected Drawdown Pumping Well (m)
Well 2	0.53	0.11	0.48	0.77
Well 1B	0.03	38.3	0.11	-
MW21-10	0.02	60.5	0.09	-
MW21-09	0.005	91.5	0.06	-
Well 3	N/A	93.3	0.06	-
MW21-08	0.005	123.5	0.03	-
Well 4	N/A	125.6	0.04	-
MW21-07	0.005	143.3	0.04	-
MW21-02	0.02	175.9	0.02	-
MW21-03	0.005	178.7	0.01	-
MW21-05	0.0	170.7	0.01	-
MW21-04	0.005	208.4	0.01	-
MW21-01	0.0	224.8	0.03	-
MW21-06	0.015	592.7	0.0	-

9.5.1 Well 2 Pumping Test Conclusions

The maximum observed drawdown in Well 2 during the pumping test was 0.53 m. The simulated corrected drawdown was 0.77 m. The model generally over predicted drawdown by a minor amount in the Well 2 pumping test. Observed drawdowns in all observation wells except the Well 2 pumping well and Well 1B could be the result of natural variations in water levels.

10.0 Updated Groundwater Model - Norwood Municipal Water Supply

The 2018 updated groundwater model (MODFLOW2005 using the graphical user interface Groundwater Vistas) [model] was used in this modelling exercise and modified with the results of the 2021 and 2022 hydraulic conductivity fields and storage parameters based on the Aquifer testing results. These new inputs were verified with the simulation of the four pumping tests where the simulated drawdowns aligned with the drawdowns observed during Aquifer testing.

10.1 Discussion - Norwood Municipal Well Field 2022 Updated Groundwater Model

The 25-year WHPAs generated in the 2022 model differs somewhat from the 2018 updated model. In the 2022 model, the aquifer parameters and aerial extent of the hydraulic conductivity (K) fields were refined. The hydraulic conductivity field representing the high permeability core deposits is narrower in the northeast-southwest direction than in the 2018 model. The Aquifer testing results, with the exception of the drawdown observations in the Well 4 pumping test in the pumping well itself, reflected hydraulic conductivities between 45 and 300 m/day.

The response of Well 4 during the pumping test was anomalous as indicated by the composite chart of drawdowns. The response indicates that Well 4 is in a part of the aquifer that had different characteristics from those of the nearby observation wells. In addition, the drawdown curve of Well 4 did not follow the usual Theis curve as expected, (water level change slowing as the test advanced) but instead showed increasing drawdown as the test advanced. This indicates the potential for a hydraulic boundary in the early portion of the test. This boundary was likely a significantly reduced hydraulic conductivity of lower permeability materials adjacent to the core deposits which was confirmed from observations during drilling and from grain size analyses.

In the 2022 updated model, the high permeability zone was extended north and south along the Norwood esker to the limits of the model. Whether this zone exists and its aerial extent to the northeast and southwest of the Municipal Well Field cannot be determined based on the Aquifer testing results. The 2022 groundwater model simulates the drawdowns during the pumping test relatively well with the high permeability zone extending to the edges of the model domain in both the northeast and southwest directions.

The 25-year WHPA veers north from the northeast-southwest trend of the Norwood esker approximately three kilometres (km) from the Norwood village centre. In this area, a bedrock high likely controlled the Norwood esker deposition and also may have some influence on the groundwater flow directions. Groundwater in this area flows from the northwest and flows around this bedrock high. Since backward tracking pathlines follow the groundwater flow direction (but in reverse) it is not surprising that the pathlines veer from the Norwood esker.

During the continuous pumping of the Water Supply Wells at the PTTW rate simulated in the groundwater model, most of the water pumped from the Water Supply Wells comes from the Norwood esker northeast of the Municipal Well Field. At the current average pumping rate (just less than 700 m³/day in December 2021-January 2022) and with the Water Supply Wells pumping intermittently depending on demand, the drawdown due to pumping is minimal as seen during the pumping tests. While much of the groundwater flow comes from the northeast in the Norwood esker, a component of groundwater flow comes from the northwest. This pattern can be seen in the Static Groundwater Contour Map included as **Figure 5**, and the extent of the drawdown cones of Wells 3 and 4 during the 2021-2022 pumping tests. Currently, some of the precipitation falling on the northwest side of the Norwood esker and beyond to the area of MW21-01 to MW21-04 infiltrates and reaches the saturated portion of the Aquifer where it will flow relatively rapidly to the Water Supply Wells. This pattern will continue for many years and may be a perennial feature depending on the

cycle times and demands of the Water Supply Well pumps in the future, as well as locations and pumping rates of newly installed Water Supply Wells, if required.

There is uncertainty in the actual configuration of the high permeability core deposits. Modelling results confirmed relatively narrow but elongated northeast-southwest high permeability core deposits surrounding Well 4. The hydraulic conductivity of the material in MW21-05 and MW21-07 to MW21-10 and Well 3 appear to be an order of magnitude less than those materials surrounding Well 4.

The continuity of these high permeability core deposits are essential to the performance of the groundwater model. It may be possible that the high permeability core deposits could form a narrow corridor to the northeast from Well 4 through the area of the monitor wells at the peak of the Norwood esker. However, because eskers tend to meander, the core deposits may move northwest from Well 4 and then turn northeast.

11.0 Predictive Modelling

11.1 Long-Term Pumping at the existing PTTW Rate

The groundwater model was used to simulate the effects of pumping Municipal Wells 2, 3 and 4 at 655 m³/day each, for a total of 1,965 m³/day, the PTTW rate. **Table 11** shows the simulated groundwater levels and drawdowns in the municipal wells.

Table 11- Existing Municipal Pumping Wells, Simulated PTTW Long-Term Rate, and Simulated Drawdowns

Hypothetical Water Supply Well	Pumping Final Rate	Simulated SWL (masl)	Simulated Pumping water Level (masl)	Simulated Drawdown (m)	Estimated Top of Pump Intake Elevation (masl)
Well 4	655	197.88	196.69	1.19	192.33
Well 3	655	197.96	196.48	1.48	195.12
Well 2	655	198.23	196.83	1.40	193.76

Table 11 also shows the estimated top of the pump intake in each well. The simulated pumping levels are higher in elevation than the estimated pump intakes indicating the wells can pump continuously without the water levels in the wells falling below the pump intakes.

The drawdown from continuous pumping at the PTTW rate in MW21-06 adjacent to Mill Pond is 0.33 m. MW21-06 is located in the aquifer under Mill Pond. There was no change in water level in Mill Pond over the simulated 20 years.

Pumping continuously at 1,965 m³/d has no effect on Mill Pond and the Ouse River. The drawdown cone of the existing Water Supply Wells Pumping at 1,965 m³/d is shown on **Figure 11**.

12.0 Conclusions

Wills provides the following conclusions and recommendations based on the investigative results of the Aquifer Capacity Study:

12.1 Conclusions

- Aquifer test parameters were generated from the pumping tests carried out on Wells 1B, 2, 3 and 4 and observation wells MW21-01 to 10. While most of the test data was relatively straightforward to analyze for aquifer parameters, some of the tests were a challenge to interpret. While this is not that unusual in aquifer test analysis, the reasons for these difficulties could have been because of the configuration of the aquifer:
 - A long, relatively thin granular deposit, flanked by lower permeability deposits.
 - Variability (from boulders to silt and clay) in the texture of the core deposits.
 - The minimal drawdowns experienced even at high pumping rates. The analytical methods are based on assumptions including an 'infinite acting' aquifer and a consistent saturated aquifer thickness as well as isotropic (properties similar in all directions) conditions.
- The higher permeability deposits are quite variable in texture with significant percentages of silt and sand with a predominance of gravel and boulders. The finer materials, especially the silt and trace to minor clay fractions will affect the hydraulic conductivity of the formation.
- The aquifer test analyses involved repeated rounds of data analysis to establish representative aquifer parameters. A considerable amount of professional judgment was required to arrive at a set of parameters which were supported by the multiple lines of evidence from assessing previous reports and maps, and from computer modelling, which resulted in a consistent conceptual model of the groundwater system at Norwood.
- While a substantial volume of groundwater moves toward the Municipal Well Field from the northeast along the Norwood esker, significant groundwater also moves from the northwest. Monitor wells MW21-01 to 04 appear to experience limited drawdown especially with Well 4 pumping during the pumping test. The well logs indicate that much of the material encountered in MW21-01 to 04 was silty sand with some sandy gravel layers or lenses and appear to constitute the flank deposits or the edge of the flank deposits. However, a hydraulic connection does exist between the Municipal Well Field and these northwest monitors.
- To meet the Norwood's population requirements, the current pumping rates of the Municipal Well Field account for approximately 35% of the PTTW rate of 1,965 m³/day (averaging approximately 650 m³/day). The drawdown from pumping at this rate and pumping intermittently each day appear to be minimal. A consequence of this is that the capture zones determined by the 2022 modelling bear little resemblance to the current configuration of capture zones at current pumping rates.
- The drawdown after 36 hours of pumping at 1,782.4 m³/day in Well 4 during the December, 2021 pumping test was 0.55 m, and the drawdown in Well 1B was

between 7.68 to 8.05 m after 24 hours pumping at 1,477.6 m³/day. The drawdown in Wells 2 (at a rate of 494.4 m³/day) and 3 (at a rate of 1542.5 m³/day) were 0.70 m and 2.11 m respectively. The saturated portion of the aquifer was approximately 9.93 m (Well 4), 8.45 m (Well 3), 10.74 (Well 1B), 7.4 (Well 2) in December 2021-January 2022. Water levels appear to vary seasonally about 0.5 m in the area of the Norwood Transfer Station, north of Norwood, and this could be the case in the area of the Municipal Well Field. If this seasonal fluctuation also occurs in the area of the Water Supply Wells, then there would be more water available in spring and early summer with water levels declining in late summer into the winter. The limiting factor in supplying large amounts of water is the limited saturated thickness combined with the screen setting of the existing Water Supply Wells.

- The groundwater model of Municipal Wells 2, 3 and 4 continuously pumping (20 years) at 655 m³/day each, for a total of 1,965 m³/day (the PTTW rate) was shown to be sustainable.
 - The simulated pumping levels were higher in elevation than the estimated pump intakes, indicating the wells can pump continuously without the water levels in the wells falling below the pump intakes.
 - Pumping continuously at the PTTW rate was shown to have no effect on Mill Pond and the Ouse River.
- The simulated pumping levels are higher in elevation than the estimated pump intakes indicating the wells can pump continuously without the water levels in the wells falling below the pump intakes.


We trust that the information contained in and attached to this report meets your needs at this time. The following Statement of Limitations should be read carefully and is an integral part of this report. Do not hesitate to contact the undersigned if you have any questions or concerns.

Respectfully submitted,

Prepared by:



David Ruttan, B.A.Sc., P. Eng.
Senior Hydrogeologist/Senior Groundwater Modeller



Ian Ames, M.Sc., P.Geo.
Environmental Monitoring and
Management Lead

13.0 Statement of Limitations

This report is intended solely for The Township of Asphodel-Norwood (Client) in assessing the capacity of the Norwood Water Supply Aquifer, and is prohibited for use by others without Wills' prior written consent. This report is considered Wills' professional work product and shall remain the sole property of D.M. Wills Associates Limited (Wills). Any unauthorized reuse, redistribution of or reliance on this report shall be at the Client and recipient's sole risk, without liability to Wills. The Client shall defend, indemnify and hold Wills harmless from any liability arising from or related to the Client's unauthorized distribution of the report. No portion of this report may be used as a separate entity; it is to be read in its entirety and shall include supporting drawings and appendices.

The recommendations made in this report are based on Wills' present understanding of the project, the current and proposed site use, ground and subsurface conditions, and are based on the work scope approved by the Client and described in the report. The services were performed in a manner consistent with the level of care and skill ordinarily exercised by members of geoscience or engineering professions currently practicing under similar conditions in the same locality. No other representations, and no warranties or representations of any kind, either expressed or implied, are made. Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the sole responsibility of such third parties.

Soil, groundwater, and bedrock conditions between and beyond the test locations may differ both horizontally and vertically from those encountered at the test locations. Should any conditions within the Study Area be encountered which differ from those found at the test locations, Wills must be notified immediately in order to permit a reassessment of our recommendations. If different conditions are identified during future activities on the Site, no matter how minor, the recommendations in this report shall be considered invalid until sufficient review and written assessment of said conditions by Wills is completed.

Figures





Legend

— Township Property Boundary

Site Location Plan


Aquifer Capacity Study
Norwood, Ontario



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See scale bar
Checked	IA	Date	June 2022
Project No.	21-7128	Drawing File No.	Figure 1



Legend

- Existing Municipal Well
- Township Property Boundary

Water Supply Well Locations

Aquifer Capacity Study
Norwood, Ontario



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See scale bar
Checked	IA	Date	June 2022
Project No.	21-7128	Drawing File No.	Figure 2



Legend

- 2021 Borehole/Monitor Well
- Existing Municipal Well
- Township Property Boundary

Subsurface Investigation Plan


Aquifer Capacity Study
Norwood, Ontario



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See scale bar
Checked	IA	Date	Dec 2021
Project No.	21-7128	Drawing File No.	Figure 3





Legend

- 2021 Borehole/Monitor Well
- Municipal Well
- 190 Groundwater Contour Elevation (masl)
Showing Inferred Flow Direction
- Township Lands

Static Groundwater Level Contour Map


Aquifer Capacity Study
Norwood, Ontario



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See scale bar
Checked	IA	Date	June 2022
Project No.	21-7128	Drawing File No.	Figure 5



WELL TEST ANALYSIS

Data Set: C:\...WELL 3 P COMPOSITE.aqt
Date: 03/09/22

Time: 12:20:14

PROJECT INFORMATION

Company: WILLS
Client: NORWOOD
Project: 7128
Location: NORWOOD
Test Well: WELL 3 PUMPING TEST P WELL
Test Date: 2018

AQUIFER DATA

Saturated Thickness: 9.4 m

Anisotropy Ratio (Kz/Kr): 1.

WELL DATA

Pumping Wells			Observation Wells		
Well Name	X (m)	Y (m)	Well Name	X (m)	Y (m)
WELL 3	740367.2	4918787.2	WELL 3	740367.2	4918787.2
			MW21-05	740323.75	4918709.1
			MW21-07	740326.1	4918755.9
			MW21-08	740334.2	4918793.9
			MW21-09	740364.3	4918826
			MW21-10	740406.3	4918852.6
			MW21-03	740309	4918921
			WELL 4	740339.3	4918769.7

Well 1B Composite Pumping Test

Aquifer Capacity Study
Norwood, Ontario



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By DR

Scale See scale bar


Checked IA

Date May 2022

Project No. 21-7128

Drawing File No. Figure 6

WELL 4 DISTANCE DRAWDOWN



Legend

- Observed Drawdown (m)
- Log Observed Drawdown (m)

Maximum Drawdown Vs. Distance from Well 4


Aquifer Capacity Study
Norwood, Ontario




D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	DR	Scale	See scale bar
Checked	IA	Date	May 2022
Project No.	21-7128	Drawing File No.	Figure 7





WELL TEST ANALYSIS

Data Set: C:\...WELL 3 P COMPOSITE.aqt
Date: 03/09/22

Time: 12:20:14

PROJECT INFORMATION

Company: WILLS
Client: NORWOOD
Project: 7128
Location: NORWOOD
Test Well: WELL 3 PUMPING TEST P WELL
Test Date: 2018

AQUIFER DATA

Saturated Thickness: 9.4 m

Anisotropy Ratio (Kz/Kr): 1.

WELL DATA

Pumping Wells			Observation Wells		
Well Name	X (m)	Y (m)	Well Name	X (m)	Y (m)
WELL 3	740367.2	4918787.2	WELL 3	740367.2	4918787.2
			MW21-05	740323.75	4918709.1
			MW21-07	740326.1	4918755.9
			MW21-08	740334.2	4918793.9
			MW21-09	740364.3	4918826
			MW21-10	740406.3	4918852.6
			MW21-03	740309	4918921
			WELL 4	740339.3	4918769.7

Well 3 Composite Pumping Test

Aquifer Capacity Study
Norwood, Ontario



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By DR


Scale See scale bar

Checked IA

Date May 2022

Project No. 21-7128

Drawing File No. Figure 10



Legend

- Municipal Wells
- Drawdown Cone of Existing Municipal Wells Pumping at 1,965 m³/day

**Drawdown Cone of Wells 2, 3, and 4
Pumping at PTTW Rate – 1,965 m³/day
(655 m³/day each).**

Norwood Well Field, Norwood Ontario

Figure 11



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9

P. 705.742.2297
F. 705.741.3568
E. wills@dmwills.com





Drawn By J Whalen	Scale Scale: 1:50,000
Checked D Ruffan	Date August, 2022
Project No. 7128	Drawing File No. Name: 7128-CapacityFiguresJune2022

Appendix A

Regional Maps





Legend	
	Spillway
	Esker
	Till Moraines
	Subject Property Boundary

Regional Physiography Map

Capacity Study
Norwood Municipal Well Field
Township of Asphodel-Norwood



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9






P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See Scale Bar
Checked	IA	Date	May 2022
Project No.	21-7128	Drawing File No.	APP-A1



Subject Property

Legend

-  Coarse-textured glaciolacustrine deposits
– Foreshore and basinal deposits, silt and clay, minor sand and gravel
-  Glaciofluvial deposits: river deposits and delta topset facies – Gravelly deposits
-  Ice-contact stratified deposits: sand and gravel, minor silt, clay and till – In moraines, eskers, kames and crevasse fills
-  Esker
-  Subject Property Boundary



Regional Surficial Geology Map

Capacity Study
Norwood Municipal Well Field
Township of Asphodel-Norwood



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9
P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See Scale Bar
Checked	IA	Date	May 2022
Project No.	21-7128	Drawing File No.	APP-A2





Subject Property



0 300 600 900 m

Legend

-  Middle Ordovician, Ottawa Group- Limestone, dolostone, shale, arkose, sandstone
-  Subject Property Boundary

Regional Bedrock Geology Map
Capacity Study
Norwood Municipal Well Field
Township of Asphodel-Norwood



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario
Canada K9J 0B9
P. 705.742.2297
F. 705.749.9944
E. wills@dmwills.com

Drawn By	LT	Scale	See Scale Bar
Checked	IA	Date	May 2022
Project No.	21-7128	Drawing File No.	APP-A3

Appendix B

Borehole Logs & Monitor Well Construction Details





D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

BORING NUMBER BH21-11

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood PROJECT NAME Norwood Aquifer Capacity and Vulnerability
PROJECT NUMBER 21-7128 PROJECT LOCATION Norwood, Ontario
DATE STARTED 11/22/21 COMPLETED 11/23/21 UTM EASTING 262393.4256 NORTHING 4918639.4989
DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 218.72 masl
DRILLING METHOD 8" Hollow Stem Auger/Mud Rotary with Split Spoons GROUNDWATER LEVELS:
LOGGED BY LT CHECKED BY IA AT END OF DRILLING ---
NOTES 8" Hollow Stem Auger 0.00 m to 1.50 m, Mud Rotary 1.50 m to 15.85 m AFTER DRILLING ---

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	GRAPHIC LOG	MATERIAL DESCRIPTION	
	SS-1	38	3		0.05 TOPSOIL: Dark brown silty sand topsoil, trace clay, rootlets, moist, loose	218.67
	SS-2	46	23		SILTY SAND: Brown silty sand, some gravel, trace clay, occasional cobble, moist, compact -trace gravel	
	SS-3	17	15		3.05 GRAVEL: Grey gravel, trace sand, trace silt, compact	215.67
5	SS-4	31	17			
	SS-5	31	23		-occasional cobble	
	SS-6	54	10		-coarse grained sand bed (upper 0.1 m of split spoon), some gravel, trace silt -some sand	
10	SS-7	48	13		-coarse sand and gravel, trace silt	
	SS-8	0	50+		-very dense	
	SS-9	40	50+			
	SS-10	38	50+		13.70 -boulder, compact	205.02
15	SS-11	8	50+		SAND: Grey brown sand (coarse to medium grained), trace to some silt, occasional cobble/boulder, very dense -increasing cobble/boulder content	202.87
					15.85 Borehole terminated at 15.85 m in sand due to practical refusal on cobble/boulder material.	



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-01

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/15/21 COMPLETED 11/15/21

UTM EASTING 262542.5859 NORTHING 4918931.382

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 202.23 masl

DRILLING METHOD 8" Hollow Stem Auger with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES

▼ AFTER DRILLING 4.06 m / Elev 198.17 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM	
							Casing Top Elev: 203.27 (m) Casing Type: Monument	
	SS-1	50	3	<u>Static Water Level</u> 3.75 mbg Dec 3/21 <u>GSA SS-5:</u> Gravel - 0% Sand - 61% Silt - 35% Clay - 4%	0.10	<u>TOPSOIL:</u> Dark brown silty sand topsoil, trace clay, moist, loose	202.13	<p>Cement seal at surface</p> <p>Bentonite hole plug seal</p> <p>Quartz sand 1.52 m length 10 slot screen</p>
	SS-2	67	28		1.50	<u>SILTY SAND:</u> Medium brown silty sand, trace clay, moist, loose	200.73	
	SS-3	46	39			<u>SAND:</u> Brown sand, some silt, trace gravel, moist, dense -some gravel, occasional cobble		
5	SS-4	75	25			-gravel and coarse sand, saturated, compact -trace gravel		
	SS-5	87	18			-interbedded coarse and fine grained sand, silty, no gravel		
	SS-6	100	46		8.10 8.25	<u>GRAVEL AND SAND:</u> Grey gravel and sand, trace silt, trace clay, abundant cobble/boulder, dense Borehole terminated at 8.25 m in gravel and sand due to practical refusal on cobble/boulder material.	194.13 193.98	



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-02

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/15/21 COMPLETED 11/16/21

UTM EASTING 262399.661 NORTHING 4918847.0905

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 208.24 masl

DRILLING METHOD 8" Hollow Stem Auger/Mud Rotary with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES 8" Hollow Stem Auger to 6.10 m, Mud Rotary 6.10 m to 16.80 m

▼ AFTER DRILLING 10.15 m / Elev 198.09 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
							Casing Top Elev: 209.29 (m) Casing Type: Monument
	SS-1	42	13			0.10 / TOPSOIL: Dark brown silty sand topsoil, trace clay, moist, loose	208.14 / Cement seal at surface
	SS-2	62	12			1.50 / SAND: Brown sand, some gravel, trace silt, trace clay, occasional cobble, moist, compact	206.74
	SS-3	44	27			SAND AND GRAVEL: Brown sand and gravel, some silt, trace clay, occasional cobble, moist, compact	
5	SS-4	67	22				
	SS-5	56	42				
	SS-6	40	28				
	SS-7	46	25				
10	SS-8	56	26	Static Water Level 10.15 mbg Dec 3/21		7.80 / SAND: Brown sand, some gravel, some silt, trace clay, occasional cobble/boulder -trace gravel	200.44
	SS-9	75	26				
	SS-10	83	20				
15	SS-11	87	30	GSA SS-11b: Gravel - 0% Sand- 70% Silt-25% Clay-5%		-sandy gravel bed (0.2 m thick), dense -interbedded fine and coarse sand, silty, no gravel	
	SS-12	29	50+			-very dense, increasing cobble/boulder content	191.44
						Borehole terminated at 16.80 m in sand due to practical refusal on cobble/boulder material.	

TESTING 7128 BOREHOLE LOGS.GPJ OVERBURDENBHLOG.NVALUE.GDT 5/25/22



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-03

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/17/21 COMPLETED 11/17/21

UTM EASTING 262370.6982 NORTHING 4918822.6306

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 208.8 masl

DRILLING METHOD 6" Solid Stem Auger/Mud Rotary with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES 6" Solid Stem Auger to 4.60 m, Mud Rotary 4.60 m to 17.50 m

▼ AFTER DRILLING 9.99 m / Elev 198.81 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
							Casing Top Elev: 209.92 (m) Casing Type: Monument
	SS-1	29	14		0.08	TOPSOIL: Dark brown silty sand topsoil, trace clay, rootlets, moist, compact	208.72
					1.50	SAND AND GRAVEL: Brown sand and gravel, some silt, trace clay, occasional cobble, moist, compact	207.30
	SS-2	65	8				
	SS-3	52	16				
5	SS-4	29	50+		4.60	SAND: Brown sand (coarse grained), trace gravel, trace silt, trace clay, moist, loose -medium grained sand, compact -some gravel, occasional cobble	204.20
	SS-5	71	23				
	SS-6	50	26				
				Static Water Level 9.99 mbg Dec 3/21	8.50	SANDY GRAVEL: Grey brown sandy gravel (coarse grained sand), trace silt, occasional cobble, very dense -fine grained sand over 0.15 m, compact	200.30
10	SS-7	65	32			SAND: Brown sand (medium grained), trace silt, trace clay, trace gravel, dense -some silt	
	SS-8	77	41	GSA SS-7: Gravel - 3% Sand- 76% Silt-17% Clay-4%		-gravelly sand bed (0.2 m thick), compact	
						-some gravel, occasional cobble/boulder	
	SS-9	58	19				
	SS-10	69	21				
				GSA SS-11: Gravel - 4% Sand- 70% Silt-22% Clay-4%		-silty, trace gravel -fine grained sand fraction	
15	SS-11	54	21		16.50		192.30
	SS-12	35	50+		17.50	SANDY GRAVEL: Grey sandy gravel, trace silt, trace clay, abundant cobble/boulder, very dense Borehole terminated at 17.50 m in sandy gravel due to practical refusal on cobble/boulder material.	191.30

Cement seal
at surface

Bentonite hole
plug seal

Quartz sand
1.52 m length
10 slot screen



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-04

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/18/21 COMPLETED 11/18/21

UTM EASTING 262313.0887 NORTHING 4918780.278

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 202.57 masl

DRILLING METHOD 6" Solid Stem Auger/Mud Rotary with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES

▼ AFTER DRILLING 3.48 m / Elev 199.09 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
							Casing Top Elev: 203.58 (m) Casing Type: Monument
	SS-1	58	6	<u>Static Water Level</u> 3.48 mbg Dec 3/21		0.10 / TOPSOIL: Dark brown silty sand topsoil, trace clay, rootlets, moist, compact	202.47 / Cement seal at surface
	SS-2	56	4			SAND: Brown sand (medium grained), trace silt, trace clay, trace gravel, occasional cobble/boulder, loose	
	SS-3	77	6			▼ -fine textured sand fraction, no gravel -light brown	
5	SS-4	79	11			-brown, coarse textured sand fraction, trace gravel, wet, compact	← Bentonite hole plug seal
	SS-5	100	3			-loose	
	SS-6	100	11			-grey brown, compact	
10	SS-7	100	16	<u>GSA SS-8A:</u> Gravel - 3% Sand - 83% Silt - 11% Clay - 3%		-some silt, increasing cobble/boulder content, very dense	← Quartz sand 1.52 m length 10 slot screen
	SS-8	100	90			11.50	191.07
Borehole terminated at 11.50 m in sand due to practical refusal on cobble/boulder material.							



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-05

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/18/21 COMPLETED 11/21/21

UTM EASTING 262369.7851 NORTHING 4918610.3916

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 216.98 masl

DRILLING METHOD 8" Hollow Stem Auger/Mud Rotary with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES 8" Hollow Stem Auger to 7.60 m, Mud Rotary 7.60 m to 23.10 m

▼ AFTER DRILLING 19.64 m / Elev 197.34 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
							Casing Top Elev: 218.16 (m) Casing Type: Monument
	SS-1	58	3			0.30 TOPSOIL: Dark brown silty sand topsoil, trace clay, rootlets, moist, loose	216.68 Cement seal at surface
	SS-2	58	53			SAND: Brown sand, some silt, trace gravel, trace clay, occasional cobble, very dense	
	SS-3	67	27			-grey brown medium grained sand fraction, some gravel, dense	
5	SS-4	44	51			-trace silt, very dense	
	SS-5	50	38			-fine grained sand fraction, increasing cobble content, dense	
	SS-6	58	50+			-trace gravel, very dense	
	SS-7	50	70			8.50 SAND AND GRAVEL: Grey sand and gravel, trace silt, trace clay, occasional cobble, very dense	208.48
10	SS-8	17	50+				
	SS-9	58	37			-dense	
	SS-10	75	72	GSA SS-10: Gravel - 40% Sand- 46% Silt-11% Clay-3%		-very dense	
15	SS-11	73	60			15.20 SAND: Grey brown sand, some gravel to gravelly, trace silt, trace clay, occasional cobble, very dense	201.78
	SS-12	99	65			-some silt	
	SS-13	42	50+			18.30 SANDY GRAVEL: Grey brown sandy gravel, some silt, trace clay, occasional cobble/boulder	198.68
20	SS-14	75	113	Static Water Level 19.63 mbg Dec 6/21			
	SS-15	62	50+	GSA SS-15: Gravel - 3% Sand- 83% Silt-11% Clay-3%		-fine grained sand bed (0.3 m thick), some silt, trace clay, trace gravel	
						-increasing cobble/boulder content, very dense	193.88
						23.10 Borehole terminated at 23.10 m in sandy gravel due to practical refusal on cobble/boulder material.	

TESTING 7128 BOREHOLE LOGS.GPJ OVERBURDENBLOG.NVALUE.GDT 5/25/22



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-06

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/30/21 COMPLETED 11/30/21

UTM EASTING 262838.8228 NORTHING 4919201.2321

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 202.21 masl

DRILLING METHOD 8" Hollow Stem Auger with Split Spoons




GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES

▼ AFTER DRILLING 3.54 m / Elev 198.67 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM		
							Casing Top Elev: 203.17 (m) Casing Type: Monument		
5	SS-1	42	2	Static Water Level 3.54 mbg Dec 3/21		0.03 TOPSOIL: Dark brown silty sand topsoil, trace clay, moist, loose	202.18	 Cement seal at surface Bentonite hole plug seal Quartz sand 1.52 m length 10 slot screen	
	SS-2	25	4			SAND: Brown sand, some gravel, trace silt, moist, loose -some silt, occasional cobble	198.51		
	SS-3	58	14			3.70 ▼ SILTY SAND AND GRAVEL: Grey brown silty sand and gravel, wet, occasional cobble, compact	197.66		
	SS-4	96	8			SAND: Grey (coarse grained) sand, some gravel, some silt, trace clay, saturated, loose - occasional cobble, compact			
	10	SS-5	56	16	GSA SS-7: Gravel - 3% Sand- 76% Silt-17% Clay-4%				
		SS-6	75	24					
		SS-7	100	13			10.00 -trace gravel, silty		192.21
Borehole terminated at 10.00 m on assumed bedrock.									



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-07

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/24/21 COMPLETED 11/26/21

UTM EASTING 262375.3874 NORTHING 4918656.8643

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 216.47 masl

DRILLING METHOD Mud Rotary with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES

▼ AFTER DRILLING 19.12 m / Elev 197.35 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
							Casing Top Elev: 217.6 (m) Casing Type: Monument
						Augered through 2.74 m thick drill pad (granular fill)	Cement seal at surface
						2.70 213.77	
	SS-1	38	68			GRAVEL: Grey brown gravel, some sand (coarse grained), trace silt, trace clay, very dense	
5	SS-2	54	16			sandy, some silt, compact	
	SS-3	42	48			-some sand, trace silt, occasional cobble, dense	
	SS-4	50	44				
10	SS-5	33	40				
	SS-6	58	23			10.70 205.77	
	SS-7	27	50+			SAND: Brown sand (fine grained), trace silt, trace clay, compact	
						12.20 204.27	
						GRAVEL AND SAND: Grey brown gravel and sand, some silt, trace clay, occasional cobble/boulder, very dense	
15	SS-8	50	48			-dense	Bentonite hole plug seal
	SS-9	46	87	Static Water Level 19.12 mbg Dec 3/21		▼ -very dense	
20	SS-10	54	59				
	SS-11	48	46			-dense -silty sand bed (0.05 m thick)	
25	SS-12	96	50+	GSA SS-12: Gravel - 44% Sand - 40% Silt - 13% Clay - 3%		-increasing cobble/boulder content -very dense	
						27.80 188.67	Quartz sand 1.52 m length 10 slot screen
						Borehole terminated at 27.80 m in gravel and sand due to practical refusal on cobble/boulder material.	

TESTING 7128 BOREHOLE LOGS.GPJ OVERBURDENBHLOG.NVALUE.GDT 5/25/22



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-08

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

DATE STARTED 11/26/21 COMPLETED 11/29/21

UTM EASTING 262386.2744 NORTHING 4918694.1027

DRILLING CONTRACTOR Canadian Environmental Drilling & Contractors Inc. GROUND ELEVATION 217.89 masl

DRILLING METHOD Mud Rotary with Split Spoons

GROUNDWATER LEVELS:

LOGGED BY LT CHECKED BY IA

AT END OF DRILLING ---

NOTES

▼ AFTER DRILLING 20.59 m / Elev 197.30 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	N VALUE	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
							Casing Top Elev: 218.83 (m) Casing Type: Monument
						Augered through 1.50 m thick drill pad (granular fill)	Cement seal at surface
	SS-1	75	26			1.50 216.39 1.60 216.29 TOPSOIL: Dark brown silty sand topsoil, trace clay, rootlets, moist, compact GRAVEL: Grey brown gravel, some sand, trace silt, trace clay, occasional cobble -medium grained sand fraction	
5	SS-2	23	14			-sand and gravel, coarse grained sand fraction	
	SS-3	42	19			-sandy	
10	SS-4	71	36				
	SS-5	62	36			13.70 204.19 GRAVELLY SAND: Grey brown gravelly sand, trace silt, trace clay, occasional cobble	Bentonite hole plug seal
15	SS-6	58	53	GSA SS-6: Gravel - 57% Sand- 28% Silt-12% Clay-3%		16.70 201.19 SANDY GRAVEL: Grey brown sandy gravel, some silt, trace clay, occasional cobble, very dense	
20	SS-7	54	80	Static Water Level 20.59 mbg Dec 6/21		22.90 194.99 SAND: Brown sand (fine grained), trace silt, compact	
25	SS-8	58	28			25.90 191.99 GRAVEL AND SAND: Grey brown gravel and sand, some silt, trace clay, occasional cobble/boulder, very dense	Quartz sand 1.52 m length 10 slot screen
	SS-9	42	50+	GSA SS-9: Gravel - 45% Sand- 35% Silt-16% Clay-4%		26.95 190.94 Borehole terminated at 26.95 m in gravel and sand due to practical refusal on cobble/boulder material.	



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-09

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood

PROJECT NUMBER 21-7128

DATE STARTED 11/29/21 **COMPLETED** 12/1/21

DRILLING CONTRACTOR Insitu Contractors Inc.

DRILLING METHOD Sonic Drilling with Continuous Sampling

LOGGED BY LT **CHECKED BY** IA

NOTES

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT LOCATION Norwood, Ontario

UTM EASTING 262418.6275 **NORTHING** 4918723.8931

GROUND ELEVATION 216.54 masl

GROUNDWATER LEVELS:

AT END OF DRILLING ---

▼ AFTER DRILLING 19.20 m / Elev 197.34 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
						Casing Top Elev: 217.38 (m) Casing Type: Monument
	ST-1	71			0.20 TOPSOIL: Dark brown silty sand topsoil, trace clay, rootlets 216.34	Cement seal at surface
	ST-2	60			2.10 SAND: Brown sand, trace to some silt, trace clay 214.44 -some silt -trace silt, trace gravel	
5					5.20 GRAVELLY SAND: Grey brown gravelly sand, trace silt, trace clay, occasional cobble 211.34 -trace gravel	
	ST-3	66			GRAVEL: Grey brown gravel, some sand, trace to some silt, trace clay, occasional cobble	
10	ST-4	80	GSA ST-4A: Gravel - 81% Sand- 18% Silt & Clay-1%		-trace silt, medium grained sand fraction	
	ST-5	100			-some silt -sandy	Bentonite hole plug seal
15	ST-6	100			-abundant cobbles -some sand	
20	ST-7	80	Static Water Level 19.20 mbg Dec 2/21	▼	-coarse grained sand fraction	
	ST-8	85			-sandy	
25	ST-9	95	GSA ST-9: Gravel - 56% Sand- 30% Silt-11% Clay-3%			Quartz sand 1.52 m length 10 slot screen
					26.50 190.04	

Borehole terminated at 26.50 m in sandy gravel due to practical refusal on cobble/boulder material.

TESTING 7128 BOREHOLE LOGS.GPJ OVERBURDENBLOGVALUE.GDT 5/25/22



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

WELL NUMBER MW21-10

PAGE 1 OF 1

CLIENT Township of Asphodel-Norwood
PROJECT NUMBER 21-7128
DATE STARTED 12/1/21 COMPLETED 12/2/21
DRILLING CONTRACTOR Insitu Contractors Inc.
DRILLING METHOD Sonic Drilling with Continuous Sampling
LOGGED BY LT CHECKED BY IA
NOTES _____

PROJECT NAME Norwood Aquifer Capacity and Vulnerability
PROJECT LOCATION Norwood, Ontario
UTM EASTING 262462.7064 NORTHING 4918747.46
GROUND ELEVATION 219.68 masl
GROUNDWATER LEVELS:
AT END OF DRILLING ---
AFTER DRILLING 22.31 m / Elev 197.37 m

DEPTH (m)	SAMPLE TYPE NUMBER	RECOVERY %	REMARKS	GRAPHIC LOG	MATERIAL DESCRIPTION	WELL DIAGRAM
						Casing Top Elev: 220.61 (m) Casing Type: Monument
	ST-1	80			0.30 TOPSOIL: 0.70 Dark brown silty sand topsoil, trace clay, rootlets	219.38 218.98
5	ST-2	70			SILTY SAND: Medium brown silty sand, trace clay	
					GRAVEL AND SAND: Grey brown gravel and sand, trace to some silt, trace clay, occasional cobble -some silt, well graded sand fraction	
					-trace silt	
10	ST-3	80			8.60	211.08
					9.30 GRAVEL: Grey gravel, trace sand, trace silt	210.38
	ST-4	80			SAND: Grey brown sand (interbedded fine and coarse grained), trace silt -some gravel	208.08
15	ST-5	86			11.60 GRAVEL AND SAND: Grey brown gravel and sand, some silt, trace clay, occasional cobble/boulder	
					-fine to medium grained sand fraction	
20	ST-6	90				
			GSA ST-7B: Gravel - 34% Sand - 38% Silt - 22% Clay - 6%		-sand and gravel, silty, well graded, sand fraction	
	ST-7	100			-trace silt, coarse grained sand fraction	
25	ST-8	57			Static Water Level 22.31 mbg Dec 6/21	
	ST-9	100				
			GSA ST-10: Gravel - 53% Sand - 35% Silt - 7% Clay - 5%		-gravel and sand	
30	ST-10	85				
					30.65	189.03
Borehole terminated at 30.65 m in gravel and sand.						Quartz sand 1.52 m length 10 slot screen

TESTING 7128 BOREHOLE LOGS.GPJ OVERBURDENBLOGVALUE.GDT 5/25/22

Appendix C

Geologic Cross-Sections





D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9


Cross Section A - A'

CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario






D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

Cross Section B-B'

CLIENT Township of Asphodel-Norwood
PROJECT NUMBER 21-7128

PROJECT NAME Norwood Aquifer Capacity and Vulnerability
PROJECT LOCATION Norwood, Ontario



TEST 7128 BOREHOLE LOGS.GPJ OVERBURDENHLOG.GDT 5/26/22



D.M. Wills Associates Limited
150 Jameson Drive
Peterborough, Ontario K9J 0B9

Cross Section C-C'


CLIENT Township of Asphodel-Norwood

PROJECT NAME Norwood Aquifer Capacity and Vulnerability

PROJECT NUMBER 21-7128

PROJECT LOCATION Norwood, Ontario

TEST 7128 BOREHOLE LOGS.GPJ OVERBURDENHLOG.GDT 5/26/22



- Gravel
- Sandy Gravel
- Sand
- Gravelly Sand
- Silty Sand
- Fill
- Bedrock
- Topsoil
- Measured Water Level
- Water Table
- Inferred Contact
- Inferred Contact (Higher Uncertainty)
- Known Contact
- P.L. Property Line

Appendix D

Pumping Tests – Observation Well Details



Appendix D - Pumping Test Observation Well Details

Well 1b Pumping Test			
Well ID	Well Depth	Well Stick Up	Static Water Level
MW21-01	8.68	1.04	5.15
MW21-02	16.89	1.05	11.55
MW21-03	18.6	1.12	10.99
MW21-04	12.49	1.01	4.82
MW21-05	24.29	1.15	20.92
MW21-06	10.97	0.97	4.35
MW21-07	29	1.13	20.36
MW21-08	27.79	0.84	21.55
MW21-09	26.36	0.8	20.14
MW21-10	31.58	0.93	23.35

Well 2 Pumping Test			
Well ID	Well Depth	Well Stick Up	Static Water Level
MW21-01	8.68	1.04	5.07
MW21-02	16.89	1.05	11.37
MW21-03	18.6	1.12	10.86
MW21-04	12.49	1.01	4.68
MW21-05	24.29	1.15	20.72
MW21-06	10.97	0.97	4.27
MW21-07	29	1.13	20.17
MW21-08	27.79	0.84	21.34
MW21-09	26.36	0.8	19.94

Well 3 Pumping Test			
Well ID	Well Depth	Well Stick Up	Static Water Level
MW21-01	8.68	1.04	4.91
MW21-02	16.89	1.05	11.21
MW21-03	18.6	1.12	10.85
MW21-04	12.49	1.01	4.64
MW21-05	24.29	1.15	20.58
MW21-06	10.97	0.97	4.34
MW21-07	29	1.13	20.25
MW21-08	27.79	0.84	21.44
MW21-09	26.36	0.8	20.04
MW21-10	31.58	0.93	23.23

Well 4 Pumping Test			
Well ID	Well Depth	Well Stick Up	Static Water Level
MW21-01	8.68	1.04	5.17
MW21-02	16.89	1.05	11.47
MW21-03	18.6	1.12	10.96
MW21-04	12.49	1.01	4.82
MW21-05	24.29	1.15	20.79
MW21-06	10.97	0.97	4.36
MW21-07	29	1.13	20.24
MW21-08	27.79	0.84	21.43
MW21-09	26.36	0.8	20.03

Appendix E

Aquifer Parameter Results for Well 3 and Well 4



Appendix E - Aquifer Parameters Derived From Well 3 and Well 4 Pumping Tests

Monitor	WELL 4 TEST		WELL 3 TEST		SATURATED THICKNESS	SATURATED THICKNESS P WELL, m	SATURATED THICKNESS P WELL, m	AVERAGE SATURATED THICKNESS, m	AVERAGE SATURATED THICKNESS, m	K AVERAGE WELL 3 m/d	K AVERAGE WELL 4 m/d
	T m ² /day	K m/d	T m ² /day	K m/d	MONITOR, m	WELL 3	WELL 4	WELL 3	WELL 4		
MW21-05											
Cooper-Jacob											
NEUMAN	1244	356.4	853	244.4	3.49	8.45	9.93	5.97	6.71	142.9	163.6
MOENCH	969	277.7	853	244.4	3.49						
geomean	1097.9	314.6	853	244.4							
MW21-05 LOGGER											
NEUMAN			1042	298.6	3.49						
MOENCH			1042	298.6	3.49	8.45	9.93	5.97	6.71	174.5	
geomean			1042	298.6							
overall geomean MW21-05		314.6	1042	270.1							
MW21-07											
NEUMAN	1516	179.8	1165	138.2	8.43						
MOENCH	1562	185.3	1182	140.2	8.43						
TARTAKOVSKY-NEUMAN	1728	205			8.43	8.45	9.93	8.44	9.18	139	174.2
geomean	1599.5	189.7	1173.5	139.2		8.45	9.93				
MW21-08 MANUAL											
NEUMAN	1395	215.9	1131	175.1	6.46						
MOENCH	1396	216.1	1080	167.2	6.46	8.45	9.93	7.455	8.195	148.3	170.3
geomean	1395.5	216	1105.2	171.1							
MW21-08 LOGGER											
NEUMAN			1024	158.5	6.46	8.45	9.93	7.455	8.195	137.4	
MOENCH			1024	158.5	6.46						
geomean			1024	158.5		8.45	9.93	4.225	4.965		
overall geomean MW21-08		216		164.7							
MW21-09											
NEUMAN	957	177.7	1256	176.9	7.1	8.45	9.93	7.775	8.515	165	122.4
MOENCH	938	177.7	1311	184.6	7.1	8.45	9.93				
TARTAKOVSKY-NEUMAN	1262	177.7			7.1	8.45	9.93				
geomean	1042.5	177.7	1283.2	180.7							
MW21-09 LOGGER											
NEUMAN			1223	172.3	7.1	8.45	9.93	7.775	8.515	157.7	
MOENCH			1229	173.1	7.1	8.45	9.93	7.775	8.515		
geomean			1226	172.7		8.45	9.93				
overall geomean MW21-09		177.7		176.7		8.45	9.93				
MW21-10						8.45	9.93				
NEUMAN	825	98.8			8.35	8.45	9.93			101.3	89.4
MOENCH	809	96.9	851	101.9	8.35	8.45	9.93	8.4	9.14		
geomean	817	97.8	851	101.9		8.45	9.93				
MW21-10 MANUAL						8.45	9.93				
THIS UNCONFINED	1355	162.3			8.35	8.45	9.93	8.4	9.14	100.5	331.3
NEUMAN			855	102.4	8.35	8.45	9.93	8.4	9.14		
MOENCH			834	99.9	8.35	8.45	9.93	8.4	9.14		
geomean			844.4	101.1		8.45	9.93				
overall geomean MW21-10				101.9		8.45	9.93				
WELL 3 OBS						8.45	9.93				
NEUMAN	1657	196.1	1271	150.4	8.45	8.45	9.93	8.45	9.19	122.6	181.5
MOENCH	1679	198.7	961	113.7	8.45	8.45	9.93	8.45	9.19		
RECOVERY MOENCH			887	105	8.45	8.45	9.93	8.45	9.19		
RECOVERY NEUMAN			1062	125.7	8.45	8.45	9.93	8.45			
geomean	1668	197.4	1035.7	122.6		8.45	9.93				
WELL 4 OBS						8.45	9.93				
MOENCH RECOVERY	1582	159.3	919	92.5	9.93	8.45	9.93	9.19	9.93	113	151.1
MOENCH	1423	143.3			9.93	8.45	9.93	9.19	9.93		
AGARWAL RECOVERY			1174	118.2	9.93	8.45	9.93	9.19	9.93		
geomean	1500.4		1038.7			8.45	9.93				
MW21-04 MANUAL						8.45	9.93				
NEUMAN	944	137.6	1510	220.1	6.86	8.45	9.93	7.655	8.395	199	114.8
MOENCH	984	143.4	1537	224.1	6.86	8.45	9.93	7.655			
geomean	963.8	140.5	1523.4	222.1		8.45	9.93				
MW21-03 MANUAL						8.45	9.93				
NEUMAN	1602	209.1	1510	197.1	7.66	8.45	9.93	8.055	8.795	189.1	168.2
MOENCH	1366	178.3	1537	200.7	7.66	8.45	9.93	8.055	8.795		
geomean	1479.3	193.1	1523.4	198.9		8.45	9.93				
MW21-02 MANUAL						8.45	9.93				
NEUMAN	2078	325.7	1453	227.7	6.38	8.45	9.93	7.415	8.155	195.9	254.8
MOENCH	2078	325.7	1452	227.6	6.38	8.45	9.93	7.415	8.155		
geomean	2078	325.7	1452.5	227.7		8.45	9.93				
MW21-01 MANUAL						8.45	9.93				
NEUMAN	482	117	1310	318	4.12	8.45	9.93	6.285	7.025	208.4	66.7
MOENCH	456	110.7	1310	318	4.12	8.45	9.93	6.285	7.025		
geomean	468.8	113.8	1310	318		8.45	9.93	4.225	4.965		
										149.1	152.5