



SUMMARY REPORT

Trentview Estates Distribution System

2025

Municipal Drinking Water License 133-102

Prepared by
Water Department
January 2026

The following summary report is prepared as legislated by the **Safe Drinking Water Act, 2002** under Ontario Regulation 170, [Schedule 22 - Summary Reports for Municipalities](#).

SAFE DRINKING WATER ACT

(O. Reg. 170/03, Sched. 22)

The following provides details of the sections and sub-sections found under **Schedule 22 - Summary Reports for Municipalities** of O. Reg. 170/03. This information has been included for your reference.

SCHEDULE 22 **SUMMARY REPORTS FOR MUNICIPALITIES**

Municipal: Large Residential, Small Residential

Application

22-1. This Schedule applies to the following drinking-water systems:

1. Large municipal residential systems.
2. Small municipal residential systems.

Report

22-2.

(1) The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (2) and (3) for the preceding calendar year and is given to,

- (a) in the case of a drinking-water system owned by a municipality, the members of the municipal council.
- (b) in the case of a drinking-water system owned by a municipal service board established under section 195 of the *Municipal Act 2001*, the members of the Municipal service board; or
- (c) in the case of a drinking-water system owned by a corporation, the board of Directors of the corporation.

(2) The report must,

- (a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and any orders applicable to the system that were not met at any time during the period covered by the report; and
- (b) for each requirement referred to in clause (a), that was not met, specify the duration of the failure and the measures that were taken to correct the failure.

(3) The report must also include the following information for enabling the owner of the system to assess the capability of the system to meet existing planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water license, or if the system is receiving all of its water from another system under an agreement pursuant to subsection 5 (4), to the flow rates specified in the written agreement.

(4) If a report is prepared under subsection (1) for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.

(5) REVOKED: O. Reg. 253/05, s. 18

Report Summary

In reference to the above legislation, the following details how this relates to the Trentview Estates Distribution System:

Application

22-1.

The Trentview Estates Distribution System is classified as “Small Municipal Residential Drinking Water System”

Report

22-2.

Sub-section (1)

This section refers to this report’s submission. The Trentview Estates DS 2025 Summary Report will be provided to council in February 2026.

Sub-section (2)

The MECP compliance inspection for the Trentview Estates DS was completed on July 15th, 2025. Table 1 included in Appendix A lists the requirements that the system failed to meet, and the measures taken to correct the failure.

A non-compliance was identified in the 2025 compliance inspection report. The non-compliance was attributed to failing to make changes to the systems registration information within 10 days of personal change. This non-compliance occurred in October 2024 as the system information was not updated within 10 days of personal changes and was addressed in June 2025.

Trentview Estates Distribution System (June 4th to July 15th, 2025) Drinking Water System Inspection Report 1-1425532613

Final Inspection Rating 98.72%

Sub-section (3)

Information included in Table 2 of Appendix A provides treated water flow data for the Trentview Estates Distribution System. The data included in this table details the total monthly, average daily and maximum daily flows to assess actual flow demands compared with the approved capacities of the facility. This data would also indicate if the facility exceeded the rated operational capacity. The rated capacity was not exceeded in 2025.

Sub-section (4)

N/A

Any questions regarding the information contained in this report should be directed to the undersigned at 705-933-4357.

Adam Terry
Manager of Water & Wastewater Operations,
Township of Asphodel Norwood

APPENDIX A

TRENTVIEW ESTATES DISTRIBUTION SYSTEM

Table 1:

The following table lists the requirements that the system failed to meet, and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Safe Drinking Water Act	NONE			
Ontario Regulations (eg. O. Reg. 170/03, O. Reg. 128/04, O. Reg. 903)	Failed to provide changes to the system registration information within 10 days of change.	October 28, 2024, to June 9, 2025	Updated system registration information, once aware changes needed to be made.	Complete
MDWL No. 133-101 and DWWP No. 133-201	NONE			
System Permit to Take Water No. 1360-98RPXS	NONE			
Provincial Officer's Order No.	NONE			

Table 2:

ANNUAL FLOW SUMMARY 2025

TRENTVIEW ESTATES DISTRIBUTION SYSTEM

Design Capacity: 160 m³/Day

Trentview Estates Distribution System – 2025 Flow Data					
Month	Total Flow (m ³ /month)	Average Daily Flow (m ³ /day)	Max. Daily Flow (m ³ /day)	Flow Rate Specified in Agreement with Trent Hills (m ³ /day)	MDWL Rated Capacity (m ³ /day)
January	606.9	19.6	23.8	160	NONE
February	512.3	18.3	21.2	160	NONE
March	541.0	17.5	19.7	160	NONE
April	573.2	19.1	25.3	160	NONE
May	810.5	26.1	32.6	160	NONE
June	874.1	29.1	44.5	160	NONE
July	1118.2	36.1	44.5	160	NONE
August	905.6	29.2	43.2	160	NONE
September	687.6	22.9	33.1	160	NONE
October	650.2	21.0	24.7	160	NONE
November	860.2	30.7	42.3	160	NONE
December	581.0	18.7	24.1	160	NONE