

Report

This report is a summary of water quality information for the Trentview Estates Distribution System published in accordance with Schedule 22 of Ontario's Drinking-Water Systems Regulation for the reporting period of January 1, 2024 to December 31, 2024. The Trentview Estates Distribution System is categorized as a Small Municipal Residential Drinking Water System (Stand Alone Distribution System).

This report was prepared for the Township of Asphodel Norwood

Who gets a copy of the Report:

- in the case of a drinking-water system owned by a municipality, the members of the municipal council;
- in the case of a drinking-water system owned by a municipal service board established under section 195 of the *Municipal Act, 2001*, the members of the municipal service board; or
- in the case of a drinking-water system owned by a corporation, the board of directors of the corporation.

What must the Report contain?

The report must,

- (a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license and any orders applicable to the system that were not met at any time during the period covered by the report; and
- (b) For each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure.

SUMMARY REPORT FOR THE TRENTVIEW ESTATES DISTRIBUTION SYSTEM

The following table lists the requirements that the system failed to meet and the measures taken to correct the failure:

Drinking Water Legislation	List the requirement(s) the system failed to meet	Specify the duration of the failure (i.e. date(s))	Describe the measures taken to correct the failure	Status (complete or outstanding)
Safe Drinking Water Act	NONE			
Ontario Regulations (eg. O. Reg. 170/03, O. Reg. 128/04, O. Reg. 903)	NONE			
MDWL No. 133-102 and DWWP No. 133-202	NONE			
System Permit to Take Water	NOT APPLICABLE – Stand Alone Distribution System			
Provincial Officer's Order No.	NONE			

What else must the Report contain?

The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water license.

Municipal Drinking Water Licence (MDWL) **No. 133-102** was issued on April 19th, 2021 which revokes Certificate of Approval No. 6008-6NRQLF. The MDWL does not specify a system rated capacity.

SUMMARY REPORT FOR THE TRENTVIEW ESTATES DISTRIBUTION SYSTEM

Trentview Estates Distribution System – 2024 Flow Data					
Month	Total Flow (m ³ /month)	Average Daily Flow (m ³ /day)	Max. Daily Flow (m ³ /day)	Flow Rate Specified in Agreement with Trent Hills (m ³ /day)	MDWL Rated Capacity (m ³ /day)
January	738.6	23.8	27.5	160	NONE
February	714.9	24.7	27.5	160	NONE
March	853.6	27.5	38.6	160	NONE
April	893.8	29.8	102.3	160	NONE
May	1233	39.8	47.1	160	NONE
June	1583.1	52.8	134.7	160	NONE
July	1000.7	32.3	134.7	160	NONE
August	1692.9	54.6	60	160	NONE
September	1772.6	50.1	71	160	NONE
October	1850	59.7	71	160	NONE
November	1306.4	43.5	73	160	NONE
December	871	28.1	62.9	160	NONE

The above table shows that there were no exceedances of the quantity of water supplied or of the maximum design rated capacity.

When Does the Report Get Submitted?

If a report is prepared for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.